



Turn over for records of visual interstitial monitoring and impressed current rectifier readings.

| If you perform Interstitial Monitoring on your tanks and/or piping and use a visual check rather than sump or interstitial sensors for your monthly leak detection, complete the table to document the monthly visual checks. | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Months of the Current Year | J | F | M | A | M | J | J | A | S | O | N | D |
| 1 | Visual check of the interstitial space of the double-walled tank indicated no release or unusual operating conditions. | | | | | | | | | | | | |
| 2 | Visual check of piping (STP, dispenser and transition) containment sumps indicates normal function and no indication of water or product. | | | | | | | | | | | | |

| Impressed Current 60 Day Rectifier Log | | | | | | | | | | | | |
|--|---|---|---|---|---|---|---|---|---|---|---|---|
| Months of the Current Year | J | F | M | A | M | J | J | A | S | O | N | D |
| Date of impressed current cathodic protection rectifier inspection. | | | | | | | | | | | | |
| Amperage reading from impressed current cathodic protection rectifier. | | | | | | | | | | | | |
| Voltage reading from impressed current rectifier. | | | | | | | | | | | | |
| Hours reading from impressed current cathodic protection rectifier. | | | | | | | | | | | | |

INSTRUCTIONS

1. The monthly UST system inspections must be conducted by or under the direction of a certified Class A/B Operator.
2. The UST Owner or Operator must maintain a copy of the walk-through inspection checklist for the most recent 12 months and shall be maintained on-site or off-site at a readily available location.