

# **Supplementary Information for Four-Factor Analyses for Selected Individual Facilities in South Dakota**

May 19, 2009

Revised Draft Report

Prepared by:

William Battye  
Janet Hou  
Brad Nelson

EC/R Incorporated  
501 Eastowne Drive, Suite 250  
Chapel Hill, North Carolina 27514

Prepared for:

Lee Gribovicz, Project Manager

Western Regional Air Partnership (WRAP) and  
Western Governors' Association (WGA)  
1600 Broadway, Suite 1700  
Denver, Colorado 80202

## **Scope of Document**

This document provides an initial analysis of the four factors which must be considered in establishing a reasonable progress goal toward achieving natural visibility conditions in mandatory Class I areas. These factors were examined for several candidate control measures for priority pollutants and emission sources. The results of this report are intended to inform policymakers in setting reasonable progress goals for the Class I areas in the Western Regional Air Partnership (WRAP) region.

This document does not address policy issues, set reasonable progress goals, or recommend a long-term strategy for regional haze. Separate documents will be prepared by the States which address the reasonable progress goals, each state's share of emission reductions, and coordinated emission control strategies.

## **Disclaimer**

The analysis described in this document has been funded by the Western Governors' Association. It has been subject to review by the WGA and the WRAP. However, the report does not necessarily reflect the views of the sponsoring and participating organizations, and no official endorsement should be inferred.

## Contents

1. Introduction .....	1-1
2. Methodology.....	2-1
2.1 Factor 1 – Costs .....	2-1
2.2 Factor 2 – Time Necessary for Compliance .....	2-2
2.3 Factor 3 – Energy and Other Impacts .....	2-2
2.4 Factor 4 – Remaining Equipment Life .....	2-3
2.5 References for Section 2.....	2-4
3. Boilers.....	3-1
3.1 Factor 1 – Costs .....	3-2
3.2 Factor 2 – Time Necessary for Compliance .....	3-2
3.3 Factor 3 – Energy and Other Impacts .....	3-3
3.4 Factor 4 – Remaining Equipment Life .....	3-4
3.5 References for Section 3.....	3-5
4. Cement Manufacturing .....	4-1
4.1 Factor 1 – Costs .....	4-4
4.2 Factor 2 – Time Necessary for Compliance .....	4-4
4.3 Factor 3 – Energy and Other Impacts .....	4-6
4.4 Factor 4 – Remaining Equipment Life .....	4-7
4.5 References for Section 4.....	4-9

### Abbreviations

BART	Best Available Retrofit Technology
CAIR	Clean Air Interstate Rule
CO <sub>2</sub>	Carbon Dioxide
EC	Elemental Carbon
EDMS	Emissions Data Management System
EPA	Environmental Protection Agency
ESP	Electrostatic Precipitator
FGD	Flue Gas Desulfurization
ICAC	Institute of Clean Air Companies
LNB	Low-NO <sub>x</sub> Burners
MW	Megawatt
NACAA	National Association of Clean Air Agencies
NEI	National Emissions Inventory
NO <sub>x</sub>	Nitrogen Oxides
OC	Organic Carbon
OFA	Overfire Air
PM	Particulate Matter
PM <sub>10</sub>	Particulate Matter Particles of 10 Micrometers or Less
PM <sub>2.5</sub>	Particulate Matter Particles of 2.5 Micrometers or Less
SCR	Selective Catalytic Reduction
SNCR	Selective Noncatalytic Reduction
SO <sub>2</sub>	Sulfur Dioxide
VOC	Volatile Organic Compounds
WRAP	Western Regional Air Partnership

# 1. Introduction

The Regional Haze Rule requires States to set reasonable progress goals toward meeting a national goal of natural visibility conditions in Class I areas by the year 2064. The first reasonable progress goals will be established for the planning period 2008 to 2018. The Western Regional Air Partnership (WRAP), along with its member states, tribal governments, and federal agencies, are working to address visibility impairment due to regional haze in Class I areas. The Regional Haze Rule identifies four factors which should be considered in evaluating potential emission control measures to meet visibility goals. These are as follows:

1. Cost of compliance
2. Time necessary for compliance
3. Energy and non-air quality environmental impacts of compliance
4. Remaining useful life of any existing source subject to such requirements

This report has been prepared as part of a project to evaluate the above factors for possible control strategies intended to improve visibility in the WRAP region. We have identified control measures for emissions of nitrogen oxides ( $\text{NO}_x$ ) and sulfur dioxide ( $\text{SO}_2$ ), which can react in the atmosphere to produce visibility-obscuring particulate matter on a regional scale, and also for direct emissions of particulate matter. For direct particulate matter (PM) emissions, we have evaluated the impacts of control measures on various particulate matter components, including  $\text{PM}_{2.5}$ ,  $\text{PM}_{10}$ , elemental carbon (EC) particulate matter, and organic carbon (OC) particulate matter. A number of emission source categories have been addressed, including:

1. Reciprocating internal combustion engines and turbines
2. Oil and natural gas exploration and production field operations
3. Natural gas processing plants
4. Industrial boilers
5. Cement manufacturing plants
6. Sulfuric acid manufacturing plants
7. Pulp and paper plant lime kilns
8. Petroleum refinery process heaters

The four-factor analyses for these emission categories are documented in a separate report, entitled “Assessing Reasonable Progress for Regional Haze in the WRAP Region – Source Category Analysis.”

The current report presents the results of a four-factor analysis of potential control measures for selected emission sources including one electric generating unit and two cement kilns at one cement manufacturing plants in South Dakota. The emission sources addressed in this current report were selected by the South Dakota Department of Environment and Natural Resources. Section 2 presents the methodology employed for the analyses, Section 3 presents the results of the four-factor analysis for boilers and Section 4 presents the results for cement kilns.

## **2. Methodology**

The first step in the technical evaluation of control measures for a source category was to identify the major sources of emissions from the category. Emissions assessments were initially based on 2002 emissions inventory in the WRAP Emissions Data Management System (EDMS),<sup>1</sup> which consists of data submitted by the WRAP states in 2004. The states then reviewed the emissions data and parameters from the EDMS used for this analysis and provided updated data when applicable. In some cases, detailed data on PM<sub>10</sub> and PM<sub>2.5</sub> emissions were not available from the WRAP inventory. Therefore, PM<sub>10</sub> and PM<sub>2.5</sub> data from the U.S. Environmental Protection Agency's (EPA) 2002 National Emissions Inventory (NEI) were used to supplement the WRAP inventory where necessary.

Once the important emission sources were identified within a given emission source category, a list of potential additional control technologies was compiled from a variety of sources, including control techniques guidelines published by the EPA, emission control cost models such as AirControlNET<sup>2</sup> and CUECost,<sup>3</sup> Best Available Retrofit Technology (BART) analyses, White Papers prepared by the Midwest Regional Planning Organization (MRPO),<sup>4</sup> and a menu of control options developed by the National Association of Clean Air Agencies (NACAA).<sup>5</sup> The options for each source category were then narrowed to a set of technologies that would achieve the emission reduction target under consideration. The following sections discuss the methodology used to analyze each of the regional haze factors for the selected technologies.

### **2.1 Factor 1 – Costs**

Control costs include both the capital costs associated with the purchase and installation of retrofit and new control systems, and the net annual costs (which are the annual reoccurring costs) associated with system operation. The basic components of total capital costs are direct capital costs, which includes purchased equipment and installation costs, and indirect capital expenses. Direct capital costs consist of such items as purchased equipment cost, instrumentation and process controls, ductwork and piping, electrical components, and structural and foundation costs. Labor costs associated with construction and installation are also included in this category. Indirect capital expenses are comprised of engineering and design costs, contractor fees, supervisory expenses, and startup and performance testing. Contingency costs, which represent such costs as construction delays, increased labor and equipment costs, and design modification, are an additional component of indirect capital expenses. Capital costs also include the cost of process modifications. Annual costs include amortized costs of capital investment, as well as costs of operating labor, utilities, and waste disposal. For fuel switching options, annual costs include the cost differential between the current fuel and the alternate fuel.

The U.S. EPA's *Guidance for Setting Reasonable Progress Goals under the Regional Haze Program*<sup>6</sup> indicates that the four-factor analyses should conform to the methodologies given in the *EPA Air Pollution Control Cost Manual*.<sup>7</sup> This study draws on cost analyses which have followed the protocols set forth in the Cost Manual. Where possible, we have used the primary references for cost data. Cost estimates have been updated to 2007 dollars using the Marshall & Swift Equipment Cost Index or the Chemical Engineering Plant Cost Index, both of which are published in the journal, *Chemical Engineering*.

For Factor 1, results of the cost analysis are expressed in terms of total cost-effectiveness, in dollars per ton of emissions reduced. A relevant consideration in a cost-effectiveness calculation is the economic condition of the industry (or individual facility if the analysis is performed on that basis). Even though a given cost-effectiveness value may, in general, be considered "acceptable," certain industries may find such a cost to be overly burdensome. This is particularly true for well-established industries with low profit margins. Industries with a poor economic condition may not be able to install controls to the same extent as more robust industries. A thorough economic review of the source categories selected for the factor analysis is beyond the scope of this project.

## **2.2 Factor 2 – Time Necessary for Compliance**

For Factor 2, we evaluated the amount of time needed for full implementation of the different control strategies. The time for compliance was defined to include the time needed to develop and implement the regulations, as well as the time needed to install the necessary control equipment. The time required to install a retrofit control device includes time for capital procurement, device design, fabrication, and installation. The Factor 2 analysis also included the time required for staging the installation of multiple control devices at a given facility.

## **2.3 Factor 3 – Energy and Other Impacts**

Table 2-1 summarizes the energy and environmental impacts analyzed under Factor 3. We evaluated the direct energy consumption of the emission control device, solid waste generated, wastewater discharged, acid deposition, nitrogen deposition, and climate impacts (e.g., generation and mitigation of greenhouse gas emissions).

In general, the data needed to estimate these energy and other non-air pollution impacts were obtained from the cost studies which were evaluated under Factor 1. These analyses generally quantify electricity requirements, steam requirements, increased fuel requirements, and other impacts as part of the analysis of annual operation and maintenance costs.

Costs of disposal of solid waste or otherwise complying with regulations associated with waste streams were included under the cost estimates developed under Factor 1, and were evaluated as to whether they could be cost-prohibitive or otherwise negatively affect the facility. Energy needs and non-air quality impacts of identified control technologies were aggregated to



estimate the energy impacts for the specified industry sectors. However, indirect energy impacts were not considered, such as the different energy requirements to produce a given amount of coal versus the energy required to produce an equivalent amount of natural gas.

**Table 2-1 Summary of Energy and Environmental Impacts  
Evaluated Under Factor 3**

<u>Energy Impacts</u>
Electricity requirement for control equipment and associated fans
Steam required
Fuel required
<u>Environmental Impacts</u>
Waste generated
Wastewater generated
Additional carbon dioxide (CO <sub>2</sub> ) produced
Reduced acid deposition
Reduced nitrogen deposition
Benefits from reductions in PM <sub>2.5</sub> and ozone, where available
<u>Impacts Not Included</u>
Impacts of control measures on boiler efficiency
Energy required to produce lower sulfate fuels
Secondary environmental impacts to produce additional energy (except CO <sub>2</sub> ) produced

## 2.4 Factor 4 – Remaining Equipment Life

Factor 4 accounts for the impact of the remaining equipment life on the cost of control. Such an impact will occur when the remaining expected life of a particular emission source is less than the lifetime of the pollution control device (such as a scrubber) that is being considered. In this case, the capital cost of the pollution control device can only be amortized for the remaining lifetime of the emission source. Thus, if a scrubber with a service life of 15 years is being evaluated for a boiler with an expected remaining life of 10 years, the shortened amortization schedule will increase the annual cost of the scrubber.

The ages of major pieces of equipment were determined where possible, and compared with the service life of pollution control equipment. The impact of a limited useful life on the

amortization period for control equipment was then evaluated, along with the impact on annualized cost-effectiveness.

## 2.5 References for Section 2

1. WRAP (2008), *Emissions Data Management System*, Western Regional Air Partnership, Denver, CO, [http://www.wrapedms.org/app\\_main\\_dashboard.asp](http://www.wrapedms.org/app_main_dashboard.asp).
2. E.H. Pechan & Associates (2005), *AirControlNET, Version 4.1 - Documentation Report*, U.S. EPA, RTP, NC, <http://www.epa.gov/ttnecas1/AirControlNET.htm>.
3. *Coal Utility Environmental Cost (CUECost) Model Version 1.0*, U.S. EPA, RTP, NC, <http://www.epa.gov/ttn/catc/products.html>.
4. MRPO (2006), *Interim White Papers-- Midwest RPO Candidate Control Measures*, Midwest Regional Planning Organization and Lake Michigan Air Directors Consortium, Des Plaines, IL, [www.ladco.org/reports/control/white\\_papers/](http://www.ladco.org/reports/control/white_papers/).
5. NACAA (formerly STAPPA and ALAPCO) (2006), *Controlling Fine Particulate Matter Under the Clean Air Act: A Menu of Options*, National Association of Clean Air Agencies, [www.4cleanair.org/PM25Menu-Final.pdf](http://www.4cleanair.org/PM25Menu-Final.pdf).
6. EPA (2007), *Guidance for Setting Reasonable Progress Goals under the Regional Haze Program*, [http://www.epa.gov/ttncaaa1/t1/memoranda/reasonable\\_progress\\_guid071307.pdf](http://www.epa.gov/ttncaaa1/t1/memoranda/reasonable_progress_guid071307.pdf).
7. EPA (2002), *EPA Air Pollution Control Cost Manual, 6th ed.*, EPA/452/B-02-001, U.S. EPA, Office of Air Quality Planning and Standards, RTP, NC, Section 5 - SO<sub>2</sub> and Acid Gas Controls, pp 1-30 through 1-42, <http://www.epa.gov/ttnecat1/products.html#cccinfo>.

### 3. Boilers

A four-factor analysis was performed on a single coal-fired boiler at Black Hill Power and Light Company – Ben French Station. This boiler is used to produce steam from the combustion of sub-bituminous coal to generate electricity in a steam turbine. The unit at BEN French Station is rated at 25 megawatts (MW). Pollutant emissions from the boilers include: nitrogen oxides (NO<sub>x</sub>), sulfur dioxide (SO<sub>2</sub>), and particulate matter (PM).

Table 2-1 summarizes the NO<sub>x</sub> and SO<sub>2</sub> emissions from the boiler, as well as the control measures used to reduce these pollutant emissions.<sup>1</sup> The pollutant emission rates shown in Table 2-1 were obtained from the WRAP 2002 emission inventory.<sup>2</sup> Emissions of EC and OC can be estimated using speciation factors from EPA's SPECIATE database.<sup>3</sup> The EC and OC components are estimated to comprise 0.021% and 0.012% of PM<sub>10</sub> emissions from coal-fired boilers, respectively.

**Table 3-1. Emissions from Selected Boilers - South Dakota**

Source Name	Facility Name	Unit ID	Unit Type	Boiler Size (MW)	NO <sub>x</sub> Annual Emissions (tons/yr)	SO <sub>2</sub> Annual Emissions (tons/yr)	Annual Emission Date
Black Hills Power and Light Co.	Ben French Station	Unit 1	Sub-bituminous coal-fired boiler	25	907.5	785.0	2002

Currently, the boiler at the Ben French Station is uncontrolled. The facility does utilize a low sulfur coal (0.33 wt %) to minimize the formation of SO<sub>2</sub> during the combustion process. A list of potential NO<sub>x</sub> and SO<sub>2</sub> control strategies are presented in Table 2-2. The table provides a range of pollutant reductions and presents the potential emission reductions from the baseline emissions by applying the listed control options.<sup>4,5</sup> These control options have been applied to many electrical generating unit boilers in the U.S. to reduce emissions of NO<sub>x</sub> and SO<sub>2</sub>.

**Table 3-2. Control Options for Selected Boilers - South Dakota**

Facility Name	Source Type	Pollutant controlled	Control Technology	Baseline emissions <sup>1</sup> (tons/yr)	Estimated control efficiency (%)	Potential controlled emissions <sup>2</sup> (tons/yr)
Ben French Station - Unit 1	Sub-bituminous coal-fired boiler	NO <sub>x</sub>	LNB	907	30 - 75	681
			LNB w/OFA		50 - 65	590
			SNCR		30 - 75	681
			SCR		40 - 90	817
		SO <sub>2</sub>	Dry sorbent injection	785	10 - 40	314
			Spray dryer absorber		90	706
			Wet FGD		90	706

<sup>1</sup> Baseline emissions obtained from 2002 EDMS database.

<sup>2</sup> Potential emission reductions calculated using the highest percentage in the estimated control efficiency range.

### 3.1 Factor 1 – Costs

Table 2-3 provides cost estimates for the emission control options which have been identified for each of the electrical generating unit boilers. For each option, the table gives an estimate of the capital cost to install the necessary equipment, and the total annual cost of control, including the amortized cost associated with the capital equipment cost. The capital cost values are expressed in terms of the cost per MW size of the boiler using EPA cost information.<sup>6,7</sup> The capital cost data was extrapolated to determine the capital cost for the larger sized boilers. The annual cost was calculated by amortizing the capital cost over 30 years at an interest rate of 7% and multiplying that value by an O&M factor. Table 2-3 also estimates the cost effectiveness for each control measure, in terms of the cost per ton of emission reduction. Recent literature<sup>8</sup> has indicated that the cost of SCR for electric generating can vary from \$120 to \$170 per kilowatt, therefore due to this variability, the capital and annual costs for SCR are presented as a range.

### 3.2 Factor 2 – Time Necessary for Compliance

Once a State decides to adopt a particular control strategy, up to 2 years will be needed to develop the necessary rules to implement the strategy. We have estimated that sources may then require up to a year to procure the necessary capital to purchase control equipment. The Institute of Clean Air Companies (ICAC) has estimated that approximately 18 months is required to design, fabricate, and install SCR or SNCR technology for NO<sub>x</sub> control, and approximately 30 months to design, build, and install SO<sub>2</sub> scrubbing technology.<sup>9</sup> Additional time of up to 12 months may be required for staging the installation process if multiple boilers are to be controlled at a single facility. Based on these figures, the total time required to achieve emission reductions for industrial boilers is estimated at a total of 5½ years for NO<sub>x</sub> strategies, and 6½ years for SO<sub>2</sub> strategies.

**Table 3-3. Estimated Costs of Control for Selected Boilers - South Dakota**

Facility Name	Pollutant controlled	Control Technology	Estimated control efficiency (%)	Estimated capital cost (\$1000)	Estimated annual cost (\$1000/yr)	Cost effectiveness (\$/ton)
Ben French Station - Unit 1	NO <sub>x</sub>	LNB	51	1,250	195	421
		LNB w/OFA	65	1,780	298	505
		SNCR	40	1,290	770	2,121
		SCR	80	3,000 - 4,250	754 - 1,068	1,039 - 1,471
	SO <sub>2</sub>	Dry sorbent injection	40	4,300	1,700	5,414
		Spray dryer absorber	90	11,600	2,670	3,779
		Wet FGD	90	14,600	2,760	3,907

<sup>1</sup> The annual cost was calculated using a 30-year equipment life and 7% interest.

<sup>2</sup> Cost effectiveness calculated from baseline emissions using the estimated control efficiency.

### 3.3 Factor 3 – Energy and Other Impacts

Table 2-4 shows the estimated energy and non-air pollution impacts of control measures for industrial boilers. The values were obtained from an EPA report listing the performance impacts of each of the control technology options.<sup>10,11</sup> In general, the combustion modification technologies (LNB, OFA) do not require steam or generate solid waste, or wastewater. They also do not require additional fuel to operate, and in some cases may decrease fuel usage because of the optimized combustion of the fuel.

Retrofitting of a SNCR requires energy for compressor power and steam for mixing. This would produce a small increase in CO<sub>2</sub> emissions to generate electricity; however the technology itself does not produce additional CO<sub>2</sub> emissions.

Installation of SCR on an industrial boiler is not expected to increase fuel consumption. However additional energy is required to operate the SCR, which will produce an increase in CO<sub>2</sub> emissions to generate the electricity. In addition, spent catalyst would have to be changed periodically, producing an increase in solid waste disposal. However, many catalyst companies accept the return of spent catalyst material.

Retrofitting of the SO<sub>2</sub> control options increase the usage of electricity, and produce both a solid waste and wastewater stream. In addition, increases of CO<sub>2</sub> emissions will occur due to the increased energy usage for material preparation (e.g., grinding), materials handling (e.g., pumps/blowers), flue gas pressure loss, and steam requirements. Power consumption is also affected by the reagent utilization of the control technology, which also affects the control efficiency of the control technology.

**Table 3-4. Estimated Energy and Non-Air Environmental Impacts of Potential Control Measures for Selected Boilers - South Dakota**

Source Type	Control Technology	Pollutant controlled	Energy and non-air pollution impacts				
			Electricity requirement (kW)	Steam requirement (lb/hr)	Solid waste produced (ton/hr)	Wastewater produced (gal/min)	Additional CO <sub>2</sub> emitted (tons/yr)
Ben French Station - Unit 1	LNB	NO <sub>x</sub>	1.2				0.0012
	LNB w/OFA	NO <sub>x</sub>	1.2				0.0012
	SNCR	NO <sub>x</sub>	7	170			0.007
	SCR	NO <sub>x</sub>	181	204			0.18
	Dry sorbent injection	SO <sub>2</sub>	265		1.5	18.3	0.3
	Spray dryer absorber	SO <sub>2</sub>	183		1.8	14.7	0.18
	Wet FGD	SO <sub>2</sub>	524		1.5	33	0.5

NOTES:

A blank cell indicates no impact is expected.

### 3.4 Factor 4 – Remaining Equipment Life

Electric generating units do not have a set equipment life. Since many of the strategies are market-based reductions applied to geographic regions, it is assumed that control technologies will not be applied to units that are expected to be retired prior to the amortization period for the specific control equipment. Therefore, the remaining life of an industrial boiler is not expected to affect the cost of control technologies for industrial boilers.

### 3.5 References for Section 3

1. NEEDS 2006.
2. WRAP(2008), *Emissions Data Management System, Western Regional Air Partnership*, Denver, CO. [http://www.wrappedms.org/app\\_main\\_dashboard.asp](http://www.wrappedms.org/app_main_dashboard.asp)
3. EPA (2006), *SPECIATE version 4*, U.S. EPA, RTP, NC.  
<http://www.epa.gov/ttn/chief/software/speciate/index.html>
4. MRPO (2006), *Interim White Paper - Midwest RPO Candidate Control Measures Source Category: Industrial, Commercial, and Institutional (ICI) Boilers*.  
[http://www.ladco.org/reports/control/white\\_papers/](http://www.ladco.org/reports/control/white_papers/)
5. NESCAUM (2009), *Applicability and Feasibility of NO<sub>x</sub>, SO<sub>2</sub>, and PM Emission Control Technologies for Industrial, Commercial, and Institutional (ICI) Boilers*.
6. Khan, Sikander (2003), *Methodology, Assumptions, and References: Preliminary NO<sub>x</sub> Controls Cost Estimates for Industrial Boilers*.
7. Khan, Sikander (2003), *Methodology, Assumptions, and References: Preliminary SO<sub>2</sub> Controls Cost Estimates for Industrial Boilers*.
8. Power Magazine (2006), *Estimating SCR Installation Costs*.  
[http://www.powermag.com/instrumentation\\_and\\_controls/Estimating-SCR-installation-costs\\_506\\_p3.html](http://www.powermag.com/instrumentation_and_controls/Estimating-SCR-installation-costs_506_p3.html)
9. Institute of Clean Air Companies (2006), *Typical Installation Timelines for NO<sub>x</sub> missions Control Technologies on Industrial Sources*.
10. Reference 6.
11. Reference 7.

## 4. Cement Manufacturing

Four-factor analyses have been conducted for selected emission sources at one South Dakota cement manufacturing plant. The following facility and emission sources have been evaluated:

- GCC Dacotah, Rapid City Plant – Cement Kilns #4 and #5

Table 3-1 outlines the baseline levels of emissions and potential additional control measures that could be adopted to further reduce emissions. The table also gives the estimated control efficiency and annual emission reduction for each potential future control measure.

Baseline emissions of  $\text{NO}_x$  and  $\text{SO}_2$  for the refineries were obtained from the WRAP 2002 emissions inventory.<sup>1</sup> Emissions of  $\text{PM}_{2.5}$  and  $\text{PM}_{10}$  were obtained from the 2002 U.S. EPA NEI and from the state of South Dakota.<sup>2</sup> Emissions of EC and OC were estimated using speciation factors from EPA's SPECIATE database.<sup>3</sup> EC and OC are estimated to comprise 0.07% and 0.014% of  $\text{PM}_{10}$  emissions from cement kilns, respectively.

The primary source of emissions from cement manufacturing plants is the cement kiln. There are four types – long wet kilns, long dry kilns, preheater kilns, and preheater/precalciner kilns. Fuels used in cement kilns include coal, natural gas, and waste-derived fuels (primarily scrap tires, but also motor oils, surplus printing inks, and sludge from the petroleum industry).<sup>4</sup>

Wet, long dry, and most preheater kilns have one fuel combustion zone; newer preheater/precalciner kilns have two fuel combustion zones and some may even have three.  $\text{NO}_x$  emissions are generated due to oxidation of molecular nitrogen present in the combustion air (i.e., thermal  $\text{NO}_x$  formation) or oxidation of nitrogen compounds within the combustion fuel (i.e., fuel  $\text{NO}_x$  formation). The temperature within the combustion zone(s) dictate, in part, the amount of  $\text{NO}_x$  formed during the production of clinker. The energy efficiency also dictates the formation of emissions, as the efficiency influences the amount of heat input required to produce cement.<sup>5</sup>  $\text{SO}_2$  emissions are created from sulfur compounds in the raw materials used (i.e., limestone, clay, sand and iron ore) and to a smaller extent in the fuel.<sup>4</sup> PM emissions are also generated by cement kilns.



**Table 4-1. Existing Control Measures and Potential Additional Control Options for Selected Cement Manufacturing Operations**

Company	Source	Pollutant	Baseline emissions (tons/yr)	Existing Control Technology	Potential Control Technology	Estimated control efficiency (%)	Potential emission reduction (tons/year)	References
GCC Dacotah, Rapid City Plant	Long Wet Kiln # 4	NO <sub>x</sub>	707	None	LNB (indirect)	30-40	212 - 283	5,11,15,19
					LNB (direct)	40	283	5,11,15,19
					Biosolid Injection	23	163	5,11,15,19
					CemSTAR	20-60	14 - 424	5,11,15,19
					Mid-Kiln	20-50	14 - 353	5,11,15,19
					SCR	80	565	10,11,14,15
	Long Wet Kiln # 5	SO <sub>2</sub>	26	None	Wet FGD	90-99	24 - 26	10,11,14,15
		PM <sub>10</sub>	136	Dry ESP	Fabric Filter	99	134	10,11,14,15
		PM <sub>2.5</sub>	67	Dry ESP	Fabric Filter	99	67	10,11,14,15
		EC	10	Dry ESP	Fabric Filter	99	9.38	10,11,14,15
		OC	2	Dry ESP	Fabric Filter	99	1.876	10,11,14,15
		NO <sub>x</sub>	388	None	LNB (indirect)	30-40	116 - 155	5,11,15,19
					LNB (direct)	40	155	5,11,15,19
					Biosolid Injection	23	89	5,11,15,19
					CemSTAR	20-60	78 - 233	5,11,15,19
					Mid-Kiln	20-50	78 - 194	5,11,15,19
					SCR	80	310	10,11,14,15
		SO <sub>2</sub>	431	None	Wet FGD	90-99	388 - 427	10,11,14,15
		PM <sub>10</sub> , PM <sub>2.5</sub> , EC, OC	45	Dry ESP	Fabric Filter	82	37	2, 10,11,14,15

The GCC Dacotah Rapid City Plant cement kilns analyzed in this report are all long wet kilns. Kilns #4 and #5 have capacities of 550 tons of clinker per day each; assuming the kilns run 365 days of the year the result is 200,750 tons of clinker per year (tpy) per kiln. NO<sub>x</sub> and SO<sub>2</sub> emissions from the Kiln #4 are 707 tpy and 27 tpy, respectively. NO<sub>x</sub> and SO<sub>2</sub> emissions from the Kiln #5 are 388 tpy and 431 tpy, respectively.<sup>1</sup>

Combustion control options for NO<sub>x</sub> include:

- Direct and indirect-fired low NO<sub>x</sub> burners,
- The CemStar process, and
- Mid-kiln firing.

Kilns can be considered either direct- or indirect-fired kilns. Direct-fired kilns use more than 10% of primary air (i.e., air that is used for conveying the pulverized coal from the coal mill to the kiln). Indirect-fired kilns use less than 10% of primary air. Low NO<sub>x</sub> burners can be used on either direct- or indirect-fired kilns. Low NO<sub>x</sub> burners reduce flame turbulence, delay fuel/air mixing, and establish fuel-rich zones for initial combustion, thus reducing thermal NO<sub>x</sub> formation.<sup>5</sup> The CemStar process adds a small amount of steel slag to the raw kiln feed and lower the temperature required to operate the kiln. Mid-kiln firing uses an additional feed injection mechanism and injects solid fuel into the calcining zone of a rotating kiln, thus lowering the temperature to produce clinker.

NO<sub>x</sub> removal control options include:

- Biosolid injection,
- LoTOx<sup>TM</sup>
- SCR,
- SNCR, and
- NO<sub>x</sub>OUT

Biosolid injection uses biosolids from wastewater treatment plants to lower the kiln heating temperature required to produce clinker (biosolid tipping fees are such that often the annualized cost is negative, i.e., the plant receives a credit for using the technology). In the LoTOx<sup>TM</sup> system, ozone is injected into the kiln which oxidizes NO<sub>x</sub>. The resulting higher oxides of nitrogen can then be removed by a wet scrubber.<sup>6</sup> LoTOx is licensed by the BOC group and is currently being used on the Midlothian cement wet kilns in Texas.<sup>6,15</sup> Both CemStar and biosolid injection are most feasible when there are nearby sources of steel slag or biowaste, respectively, that the cement plant can easily procure without incurring large transportation costs.

SCR uses an ammonia catalyst (such as a titanium dioxide or vanadium pentoxide mixture) to selectively reduce NO<sub>x</sub> emissions from exhaust gases by converting NO<sub>x</sub> to nitrate. The catalytic reactions can take place only in certain temperature ranges which are often higher than typical cement kiln flue gas temperatures. Process reconfigurations, such as an automatically activated bypass duct placed around the SCR reactor to control temperature fluctuations or installing equipment to maintain the desired temperature, can successfully deal

with temperature issues.<sup>6</sup> Due to potential fouling problems of the catalyst the SCR system must be installed after the particulate collection device.

SNCR also reduces NO<sub>x</sub> formation by ammonia or urea but does not use a catalyst. Instead the ammonia or urea is injected into the kiln. Similar to SCR, there is an ideal temperature range at which these reactions optimally occur. Long wet and dry kilns have the ideal temperature for SNCR reactions in the middle of the kiln, whereas preheater/precalciner kilns have the ideal temperature at the lower end of the preheater tower or at the cooler end of the kiln, i.e., not in the middle. Thus preheater/precalciner kilns are much more conducive to the SNCR technology and as such SNCR is not applicable to long wet and dry kilns.

NO<sub>x</sub>OUT is similar to the SNCR process and uses urea to complete the chemical conversion of NO to nitrate and oxygen. The temperature window is somewhat wider than typical SNCR systems due to an additive developed by the proprietors of the NO<sub>x</sub>OUT technology.<sup>5</sup>

The clinker production process controls SO<sub>2</sub> to a significant degree.<sup>7,8</sup> The interior of the kiln is highly alkaline absorbs up to 95 percent of the SO<sub>2</sub> emissions generated, although this can vary depending on the kiln feed.<sup>9</sup> The option to control SO<sub>2</sub> is limited to flue gas desulfurization (FGD).<sup>10</sup> Flue gas is the primary source of SO<sub>2</sub> and volatile organic carbons (VOCs) – the fuel and raw materials dictate the amount of SO<sub>2</sub> emissions generated. Wet scrubbers have 80-99 percent control efficiency, although the generation of sludge and particulate build-up necessitates the FGD be installed downstream of a fabric filter.<sup>11,12,13</sup> PM emissions are often controlled by fabric filters or wet or dry Electrostatic Precipitators (ESPs).<sup>14,15</sup> Kilns #4 and #5 at the GCC facility already have dry ESPs installed and thus only fabric filters are analyzed for further PM control.

#### **4.1 Factor 1 – Costs**

Table 4-2 provides cost estimates for the emission control options which have been identified for the South Dakota cement manufacturing plant. For each option, the table gives an estimate of the capital cost to install the necessary equipment (including any required instrumentation and equipment and all piping and ductwork), and the total annual cost of control, including the amortized cost associated with the capital equipment cost. The table also shows the estimated cost effectiveness for each control measure, in terms of the cost per ton of emission reduction.

#### **4.2 Factor 2 – Time Necessary for Compliance**

Once the regional haze control strategy is formulated for South Dakota, up to 2 years will be needed for the state to develop the necessary rules to implement the strategy. We have estimated that sources may then require up to a year to procure the necessary capital to purchase

**Table 4-2. Estimated Costs of Control for Selected Cement Manufacturing Operations in South Dakota**

Company	Source	Control option	Pollutant	Estimated control efficiency (%)	Potential emission reduction (tons/year)	Estimated capital cost (\$1000)	Estimated annual cost (\$1000/year)	Cost effectiveness (\$/ton)	Refer-ences
GCC Dacotah, Rapid City Plant	Long Wet Kiln # 4	LNB (indirect)	NO <sub>x</sub>	30-40	212 - 283	526	129	3,092 - 1,859	5,14,15
		LNB (direct)	NO <sub>x</sub>	40	283	1,873	331	7,788	5,14,15
		Biosolid Injection	NO <sub>x</sub>	23	163	-	-	421.41	5,14,15
		CemSTAR	NO <sub>x</sub>	20-60	14 - 424	1,599	299	4,476 - 13,459	5,14,15
		Mid-Kiln	NO <sub>x</sub>	20-50	14 - 353	2,758	-315	6,922 - 17,328	5,14,15
		LoTOx <sup>TM</sup>	NO <sub>x</sub>	80-90	565 - 636	Unknown <sup>a</sup>		3155 - 3891	6,15
		SCR	NO <sub>x</sub>	80	565	14,813	4,137	34	5,14,15
		Wet FGD	SO <sub>2</sub>	90-99	24 - 26	9,133	1,370	403,942 - 437,604	10,11,15
	Long Wet Kiln # 5		PM <sub>10</sub> , EC, OC	99	134	1,357	1,148	18,699	10,11,15
		Fabric Filter							
		Fabric Filter	PM <sub>2.5</sub>	99	67	1,235	1,045	37,399	10,11,15
		LNB (indirect)	NO <sub>x</sub>	30-40	116 - 155	526	129	4,229 - 5,651	5,14,15
		LNB (direct)	NO <sub>x</sub>	40	155	1,873	331	14220	5,14,15
		Biosolid Injection	NO <sub>x</sub>	23	89	-	-	0	5,14,15
		CemSTAR	NO <sub>x</sub>	20-60	78 - 233	1,599	299	8,144 - 24,330	5,14,15
		LoTOx <sup>TM</sup>	NO <sub>x</sub>	80-90	310 - 349	Unknown <sup>a</sup>		3155 - 3891	6,15
		Mid-Kiln	NO <sub>x</sub>	20-50	78 - 194	2,758	-315	12,594 - 31,324	5,14,15
		SCR	NO <sub>x</sub>	80	310	14,813	4,137	61	5,14,15
		Wet FGD	SO <sub>2</sub>	90-99	388 - 427	9,133	1,370	27,068	10,11,15
			PM <sub>10</sub> , PM <sub>2.5</sub> , EC, OC	82	37	1,235	1,045	110,421	2,10,11,15
		Fabric Filter							

a Cost effectiveness figures for LoTOx were not determined for dry kilns or preheater kilns, but only for wet kilns (the kilns that currently use the system) and precalciner kilns (developed from vendor information).

control equipment. The ICAC has estimated that approximately 13 months is required to design, fabricate, and install SCR or SNCR technology for NO<sub>x</sub> control.<sup>16</sup> However, state regulators' experience indicates that closer to 18 months is required to install this technology.<sup>17</sup> In the Clean Air Interstate Rule (CAIR) analysis, EPA estimated that approximately 30 months is required to design, build, and install SO<sub>2</sub> scrubbing technology for a single emission source.<sup>18</sup> The analysis also estimated that up to an additional 12 months may be required for staging the installation process if multiple sources are to be controlled at a single facility.

Based on these figures, the total time required to achieve emission reductions for the cement kilns would be up to 6½ years. This includes 2 years for regulatory development, 1 year for capital acquisition, and 2½ years for designing, building and installing a scrubber, if this option is selected. If catalyst additives are used, time will be required to select and test the appropriate additives, and to determine the optimum feed rate for the additive.

### **4.3 Factor 3 – Energy and Other Impacts**

Table 4-3 shows the estimated energy and non-air pollution impacts of control measures for sources at the Wyoming cement manufacturing plant. The table shows the additional fuel, electricity, and steam requirements needed to operate the control equipment; and the additional solid waste that would be produced. CO<sub>2</sub> emissions associated with the generation of the additional electricity and steam are also estimated in the table.

A LoTOx<sup>TM</sup> scrubbing system or wet scrubbing system applied to the fluidized catalytic cracking unit would require electricity to operate fans and other auxiliary equipment, and would produce a wastewater stream which would require treatment. In addition, sludge from the scrubber would require disposal as solid waste. SCR and SNCR systems would also require electricity for fans, and SCR may require additional heat input as the temperature at which the catalytic reactions occur can be higher than the typical cement kiln flue gas temperatures, although it may be possible to use heat recovery systems to reheat and achieve the required temperature.<sup>5</sup> However, it is possible to use heat recovery systems to reheat the exhaust and avoid generating additional heat input. There is also the additional burden of getting rid of fouled or deactivated catalyst from the system – often the PM control device in the form of a fabric filter or electrostatic precipitator can achieve this goal.<sup>5</sup> SCR systems would produce additional solid waste because of spent catalyst disposal. Dust captured by an ESP or fabric filter would also require disposal as a solid waste. The presence of catalyst fines in the dust may require treatment as a hazardous waste.<sup>19</sup>

#### 4.4 Factor 4 – Remaining Equipment Life

Information was not available on the age of the cement kilns. However, industrial processes often refurbish cement kilns to extend their lifetimes. Therefore, the remaining lifetime of most equipment is expected to be longer than the projected lifetime of pollution control technologies which have been analyzed for these sources.

If the remaining life of an emission source is less than the projected lifetime of a pollution control device, then the capital cost of the control device would have to be amortized over a shorter period of time, corresponding to the remaining lifetime of the emission source. This would cause an increase in the amortized capital cost of the pollution control option, and a corresponding increase in the total annual cost of control. This increased cost can be quantified as follows:

$$A_1 = A_0 + C \times \frac{1 - (1 + r)^{-m}}{1 - (1 + r)^{-n}}$$

where:

$A_1$  = the annual cost of control for the shorter equipment lifetime (\$)

$A_0$  = the original annual cost estimate (\$)

$C$  = the capital cost of installing the control equipment (\$)

$r$  = the interest rate (0.07)

$m$  = the expected remaining life of the emission source (years)

$n$  = the projected lifetime of the pollution control equipment

**Table 4-3. Estimated Energy and Non-Air Environmental Impacts of Potential Control Measures for Selected Cement Manufacturing Operations in South Dakota**

			Energy and non-air pollution impacts (per ton of emission reduced)						
Source Type	Control Technology	Pollutant controlled	Potential emission reduction ( tons/year)	Additional fuel requirement (%)	Electricity requirement (kW-hr)	Steam requirement (tons steam)	Solid waste produced (tons waste)	Wastewater produced (1000 gallons)	Additional CO <sub>2</sub> emitted (tons)
GCC Dacotah, Rapid City Plant	Long Wet Kiln # 4	LNB (indirect)	NO <sub>x</sub>	212 - 283	a	182			
		LNB (direct)	NO <sub>x</sub>	283	a	182			
		Biosolid Injection	NO <sub>x</sub>	163	a				
		NOXOUT	NO <sub>x</sub>	247		b			
		CemSTAR	NO <sub>x</sub>	14 - 424	a				
		Mid-Kiln	NO <sub>x</sub>	14 - 353	a				
		LoTOx™	NO <sub>x</sub>	565 - 636		c	b	b	c
		SCR	NO <sub>x</sub>	565	9.8	57			b
		Wet FGD	SO <sub>2</sub>	24 - 26	1,100	3	3.7		2.6
		Fabric Filter	PM <sub>10</sub> , EC, OC	134		b	1		
		Fabric Filter	PM <sub>2.5</sub>	67		b	1		
		Dry ESP	PM <sub>10</sub> , EC, OC	44		b	1		
		Dry ESP	PM <sub>2.5</sub>	21		b	1		
	Long Wet Kiln # 5	LNB (indirect)	NO <sub>x</sub>	116 - 155	a				
		LNB (direct)	NO <sub>x</sub>	155	a				
		Biosolid Injection	NO <sub>x</sub>	89	a				
		NOXOUT	NO <sub>x</sub>	136		b			
		CemSTAR	NO <sub>x</sub>	78 - 233	a				
		Mid-Kiln	NO <sub>x</sub>	78 - 194	a				
		LoTOx™	NO <sub>x</sub>	310 - 349		c	b	b	c
		SCR	NO <sub>x</sub>	310	9.8	57			b
		Wet FGD	SO <sub>2</sub>	388 - 427	1,100	3	3.7		2.6
		Fabric Filter	PM <sub>10</sub> , EC, OC	45		b	1		b
		Fabric Filter	PM <sub>2.5</sub>	22		b	1		
		Dry ESP	PM <sub>10</sub> , EC, OC	45.17	a	b	1		
		Dry ESP	PM <sub>2.5</sub>	22.34214973	0.5	b	1		0.0

**NOTES:**

a - The measure is expected to improve fuel efficiency.

b - Some impact is expected but insufficient information is available to evaluate the impact.

c - According to the ERG Report (reference 5) "electricity and oxygen costs are reported to be high" although there is no quantification given.

blank indicates no impact is expected.

#### 4.5 References for Section 4

1. WRAP (2008), *Emissions Data Management System*, Western Regional Air Partnership, Denver, CO, [http://www.wrappedms.org/app\\_main\\_dashboard.asp](http://www.wrappedms.org/app_main_dashboard.asp)
2. Boddicker, Rick (2009), Personal Communication, *Potential Reduction of Particulate Matter by Dry ESP*, South Dakota Department of Environment & Natural Resources, May 5.
3. EPA (2006), *SPECIATE version 4*, U.S. EPA, RTP, NC, <http://www.epa.gov/ttn/chief/software/speciate/index.html>
4. Lake Michigan Air Directors Consortium, *Interim White Paper – Midwest RPO Candidate Control Measures*, [http://www.ladco.org/reports/control/white\\_papers/](http://www.ladco.org/reports/control/white_papers/).
5. EC/R Incorporated (2000), *NO<sub>x</sub> Control Technologies for the Cement Industry*, Prepared for OAQPS/OPSP/AQSSD, EPA Contract No. 68-D98-026, <http://www.epa.gov/ttn/naaqs/ozone/rto/fip/data/cement.pdf>.
6. ERG, Inc. (2005), *Assessment of NO<sub>x</sub> Emissions Reduction Strategies for Cement Kilns - Ellis County, Chapter 4*, TCEQ Contract No. 582-04-65589, Work Order No. 05-06, [http://www.tceq.state.tx.us/assets/public/implementation/air/sip/agreements/BSA/CEMENT\\_FINAL\\_REPORT\\_70514\\_final.pdf](http://www.tceq.state.tx.us/assets/public/implementation/air/sip/agreements/BSA/CEMENT_FINAL_REPORT_70514_final.pdf).
7. Davis, W. (2000) *Air Pollution Engineering Manual: Second Edition*, Air & Waste Management Association.
8. Sumter Cement Company (2005), *Application to Construct New Portland Cement Plant, NSR/PSD Construction Permit for Center Hill Plant*, submitted to Florida Department of Environmental Protection, [www.dep.state.fl.us/Air/permitting/construction/sumter/APPLICATION.zip](http://www.dep.state.fl.us/Air/permitting/construction/sumter/APPLICATION.zip)
9. U.S. Environmental Protection Agency (1995), *Chapter 11: Mineral Products Industry: Portland Cement Manufacturing* in AP 42, Fifth Edition, Volume I, <http://www.epa.gov/ttn/chief/ap42/ch11/final/cs11s06.pdf>.
10. U.S. Department of Energy, National Energy Technology Laboratory (2001), *Cement Kiln Flue Gas Recovery Scrubber Project: A DOE Assessment*, DOE/NETL-2002/1163, <http://www.epa.gov/ttn/chief/ap42/ch11/final/cs11s06.pdf>.
11. Lake Michigan Air Directors Consortium (LADCO) (2005), *Midwest Regional Planning Organization (RPO) Cement Best Available Retrofit Technology (BART) Engineering Analysis*, Prepared by MACTEC Federal Programs/MACTEC Engineering and Consulting, Inc., [http://www.ladco.org/reports/control/bart/cement\\_plants.pdf](http://www.ladco.org/reports/control/bart/cement_plants.pdf).



- 12 Miller, F.M., G.L. Young, M. von Seebach (2001), *Formation and Techniques for Control of Sulfur Dioxide and Other Sulfur Compounds in Portland Cement Kiln Systems*, Portland Cement Association, PCA R&D Serial No. 2460, pp.37-48.
- 13 NESCAUM (2005), *Assessment of Control Technology Options for BART-Eligible Sources: Steam Electric Boilers, Industrial Boilers, Cement Plants and Paper and Pulp Facilities*, U.S. EPA Grant XA-983799-01-2, pp. 59-78,  
<http://www.nescaum.org/documents/bart-control-assessment.pdf/>
- 14 E.H. Pechan & Associates (2005), *AirControlNET, Version 4.1 - Documentation Report*, U.S. EPA, RTP, NC, <http://www.epa.gov/ttnecas1/AirControlNET.htm>
- 15 NACCA (formerly STAPPA and ALAPCO) (2006), *Controlling Fine Particulate Matter Under the Clean Air Act: a Menu of Options*, Prepared by the State and Territorial Air Pollution Program Administrators and Association of Local Air Pollution Control Officials, [www.4cleanair.org/ PM25Menu-Final.pdf](http://www.4cleanair.org/PM25Menu-Final.pdf).
- 16 . Institute of Clean Air Companies (2006), *Typical Installation Timelines for NOX Emissions Control Technologies on Industrial Sources*.  
[http://www.icac.com/files/public/ICAC\\_NOx\\_Control\\_Installation\\_Timing\\_120406.pdf](http://www.icac.com/files/public/ICAC_NOx_Control_Installation_Timing_120406.pdf).
- 17 . Ghoreishi, Farrokh (2007), Personal communication, *Time required to install add-on control measures for NO<sub>x</sub>*, Wisconsin Department of Natural Resources, April 27.
18. EPA (2005), *Boilermaker Labor Analysis and Installation Timing – Technical Support Document for the Final Clean Air Interstate Rule*. OAR-2003-0053, U.S. EPA, Washington, DC. [www.epa.gov/cair/technical.html#final](http://www.epa.gov/cair/technical.html#final)
- 19 US Environmental Protection Agency/Office of Air Quality Planning and Standards (1994), *Alternative Control Techniques Document - NO<sub>x</sub> Emissions from Cement Manufacturing*, EPA-453/R-94-004, Chapter 7,  
<http://www.epa.gov/ttn/catc/dir1/cement.pdf>.