

Town of Midland Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



2024 Certificate of Achievement Award.

Population Served:	120	System Population:	120
Certified Operator:	Mr Donald Cooper PO Box 232 Midland, SD 57552-0232	Work Phone:	(605)515-7027
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	airman13@yahoo.com; midland@gwtc.net
Financial Contact:	Ms Michelle Meinzer PO Box 232 Midland, SD 57552-0232	Work Phone:	(605)843-2810
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	midland@gwtc.net
Other Contacts:	President Carissa Zysset PO Box 232 Midland, SD 57552-0232	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cm.zysset@gmail.com
Last Inspection:	June 7, 2024	Area Served:	Haakon County
Type of System:	Community	Contract Laboratory:	State Health Lab, Pierre
Service Connections:	92	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	WR/LJ - North Stanley County (2224)		

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 30, 2023</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2026</u>
E	Lead - 90% Level	<u>1.03</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.11</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Last Qtr Cl Residual:	<u>0.93</u> mg/l
D	Running Annual Average:	<u>0.71</u> mg/l
E	Date of last DBP test:	<u>September 30, 2025</u>
F	THM - Qtr Average:	<u>30.1</u> ug/l
G	Haa5 - Qtr Average:	<u>16.4</u> ug/l

Asbestos

A	Date of last test:	<u></u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Midland

EPA ID: 0012

Violations From October 1, 2020 To October 1, 2025

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Trihalomethane (THM)	08/01/2023	Public Notice Requested
	Trihalomethane (THM)		Compliance Achieved
DBP Failure To Monitor	Haloacetic Acids (HAA5)	08/01/2023	Public Notice Requested
	Haloacetic Acids (HAA5)		Compliance Achieved
DBP Failure To Monitor	Chlorine	04/01/2023	Public Notice Requested
	Chlorine		Public Notice Received
	Chlorine		Compliance Achieved
FTM-Routine Samples	RTCR	03/01/2022	Public Notice Requested
	RTCR		Public Notice Received
	RTCR		Compliance Achieved
Lack of Certified Operator	Certified Operator	08/01/2021	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected