Woodland Hills Sanitary District Drinking Water Information

(General Information and Sampling Requirements as of November 03, 2026)



Secretary Award For Drinking Water Excellence

Population Served: 255

System Population: 255

Certified Operator: Mr Dylan Striebel
PO Box 761
Black Hawk, SD 57718-0761

Work Phone: (605)786-4366
Home Phone:
Cell Phone:
Fax:
Email: consultclearwater@gmail.com

Financial Contact: Clearwater Consulting
PO Box 761
Black Hawk, SD 57718-0761

Work Phone: (605)786-4366
Home Phone:
Cell Phone:
Fax:
Email: consultclearwater@gmail.com

Other Contacts: Mr Jim Stewart
PO Box 17
Black Hawk, SD 57718-0017

Work Phone:
Home Phone:
Cell Phone:
Fax:
Email:

Last Inspection: March 19, 2024

Area Served: Meade County

Type of System: Community

Contract Laboratory: Midcontinent Laboratory

Service Connections: 102

Contamination Risk: moderate

PWS Owner Type: Local Government

Service Area: Housing Development

Water Produced And Used By The Woodland Hills Sanitary District Public Water System

Monitoring/Reporting - Entry Point

Woodland Hills Sanitary District EPA ID: 0042

SAMPLING

Entry point: Treat Site - Well #2

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Jun-20		
	B. Arsenic	Every nine years	Yes	Jun-20		
	C. Barium	Every nine years	Yes	Jun-20		
	D. Beryllium	Every nine years	Yes	Jun-20		
	E. Cadmium	Every nine years	Yes	Jun-20		
	F. Chromium	Every nine years	Yes	Jun-20		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Jun-20		
	I. Mercury	Every nine years	Yes	Jun-20		
	J. Nickel	Every nine years	Yes	Jun-20		
	K. Selenium	Every nine years	Yes	Jun-20		
	L. Thallium	Every nine years	Yes	Jun-20		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals	Triennially	No	Jan-26		
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Jan-26		
	B. Method 524	Triennially	No	Jan-26		
	C. Method 525	Triennially	No	Jan-26		
	D. Method 531.1	Triennially	No	Jan-26		
	E. Method 547	Triennially	No	Jan-26		
	F. Method 548	Triennially	No	Jan-26		
	G. Method 549	Triennially	No	Jan-26		
5	Nitrate	Annually	N/A	Jan-26		
6	Nitrite	Triennially	N/A	Jan-26		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2025 to October 1, 2026

A	Samples submitted:	13
B	Samples required:	One Sample Monthly.
C	Survey samples:	0
D	Safe samples:	13
E	Unsafe samples:	0
F	Repeat samples:	0
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	September 13, 2023	
B	Samples required:	5	
C	Sampling Frequency	Triennially	
D	Date Due Next	2026	
E	Lead - 90% Level	3.5	Action Level - 15 ug/l
F	Copper 90% Level	0.14	Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2025 to October 1, 2026

A	Samples submitted:	13	
B	Samples required:	One Sample Monthly.	
C	Last Qtr Cl Residual:	0.87	mg/l
D	Running Annual Average:	0.81	mg/l
E	Date of last DBP test:	September 9, 2026	
F	THM - Qtr Average:	0	ug/l
G	Haa5 - Qtr Average:	0	ug/l

Asbestos

A	Date of last test:		
B	Asbestos Result:		million fibers per liter

Comments

Violations and Significant Deficiencies

Woodland Hills Sanitary District **EPA ID: 0042**

Violations From October 1, 2021 To October 1, 2026

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected