

Town of Conde Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)

Population Served:	142	System Population:	142
Certified Operator:	Mr Jake Bawek PO Box 113 Conde, SD 57434-0113	Work Phone: Home Phone: Cell Phone: Fax: Email:	 jacobbawek@gmail.com
Financial Contact:	Ms Sandy Hoops PO Box 113 Conde, SD 57434-0113	Work Phone: Home Phone: Cell Phone: Fax: Email:	(605)382-5258 (605)382-5294 ctyconde@nvc.net
Other Contacts:	President Austin Hearnen PO Box 113 Conde, SD 57434-0113	Work Phone: Home Phone: Cell Phone: Fax: Email:	 ctyconde@nvc.net
Last Inspection:	April 29, 2024	Area Served:	Spink County
Type of System:	Community	Contract Laboratory:	State Health Lab, Pierre
Service Connections:	112	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	WEB Water Development Association (1089)		

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>11</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>11</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 9, 2023</u>	
B	Samples required:	<u>5</u>	
C	Sampling Frequency	<u>Triennially</u>	
D	Date Due Next	<u>2026</u>	
E	Lead - 90% Level	<u>1</u>	Action Level - 15 ug/l
F	Copper 90% Level	<u>0.275</u>	Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>11</u>	
B	Samples required:	<u>One Sample Monthly.</u>	
C	Last Qtr Cl Residual:	<u>2</u>	mg/l
D	Running Annual Average:	<u>1.99</u>	mg/l
E	Date of last DBP test:	<u>September 23, 2025</u>	
F	THM - Qtr Average:	<u>3.96</u>	ug/l
G	Haa5 - Qtr Average:	<u>19.2</u>	ug/l

Asbestos

A	Date of last test:	
B	Asbestos Result:	million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Conde

EPA ID: 0096

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
FTM-Routine Samples	RTCR	08/01/2025	Public Notice Requested
Lack of Certified Operator	Certified Operator	11/29/2023	Reminder Notice
	DBP		Compliance Achieved
DBP Failure To Monitor	Chlorine	07/01/2023	Public Notice Requested
	Chlorine		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected