

Town of Doland Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)

Population Served:	199	System Population:	199
Certified Operator:	Mr Dave Bucholz PO Box 126 Doland, SD 57436-0126	Work Phone:	(605)635-6590
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cod-dave@hotmail.com
Financial Contact:	Ms Kamela Deslauriers PO Box 126 Doland, SD 57436-0126	Work Phone:	(605)635-6590
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	kam@nvc.net; cityofdoland@nvc.net
Other Contacts:	President Stuart Bell PO Box 126 Doland, SD 57436-0126	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	January 24, 2023	Area Served:	Spink County
Type of System:	Community	Contract Laboratory:	State Health Lab, Pierre
Service Connections:	157	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	WEB Water Development Association (1089)		

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 29, 2023</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2026</u>
E	Lead - 90% Level	<u>9.1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.285</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Last Qtr Cl Residual:	<u>2</u> mg/l
D	Running Annual Average:	<u>2.35</u> mg/l
E	Date of last DBP test:	<u>September 16, 2025</u>
F	THM - Qtr Average:	<u>4.84</u> ug/l
G	Haa5 - Qtr Average:	<u>16.6</u> ug/l

Asbestos

A	Date of last test:	<u></u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Doland

EPA ID: 0108

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected