

Town of Garden City Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



2024 Certificate of Achievement Award.

Population Served:	33	System Population:	33
Certified Operator:	Mr Alan Luckhurst 308 Grover Ave Garden City, SD 57236	Work Phone: Home Phone: (605)532-5353 Cell Phone: Fax: (605)532-3496 Email: andrea@itctel.com	
Financial Contact:	Ms Andrea Helkenn 308 Grover Ave Garden City, SD 57236-0134	Work Phone: Home Phone: Cell Phone: Fax: Email: andrea@itctel.com	
Other Contacts:	President Joyce Hansen PO Box 134 Garden City, SD 57236-0134	Work Phone: Home Phone: Cell Phone: Fax: Email:	
Last Inspection:	August 13, 2025	Area Served:	Clark County
Type of System:	Community	Contract Laboratory:	State Health Lab, Pierre
Service Connections:	43	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	Clark Rural Water System (0881)		

Bacteriological Monitoring

Bacteriological sampling and analysis:

October 1, 2024

to

October 1, 2025

A	Samples submitted:	12
B	Samples required:	One Sample Monthly.
C	Survey samples:	0
D	Safe samples:	12
E	Unsafe samples:	0
F	Repeat samples:	0
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	September 30, 2023	
B	Samples required:	5	
C	Sampling Frequency	Every Six Months	
D	Date Due Next		
E	Lead - 90% Level	2.745	Action Level - 15 ug/l
F	Copper 90% Level	0.32	Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis:

October 1, 2024

to

October 1, 2025

A	Samples submitted:	12	
B	Samples required:	One Sample Monthly.	
C	Last Qtr Cl Residual:	0.54	mg/l
D	Running Annual Average:	0.65	mg/l
E	Date of last DBP test:	August 22, 2024	
F	THM - Qtr Average:	0	ug/l
G	Haa5 - Qtr Average:	0	ug/l

Asbestos

A	Date of last test:	
B	Asbestos Result:	million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Garden City

EPA ID: 0137

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Trihalomethane (THM)	08/01/2023	Public Notice Requested
	Trihalomethane (THM)		Compliance Achieved
DBP Failure To Monitor	Haloacetic Acids (HAA5)	08/01/2023	Public Notice Requested
	Haloacetic Acids (HAA5)		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected