

City of Irene Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



Secretary Award For Drinking Water Excellence

Population Served:	422	System Population:	422
Certified Operator:	Mr Rick Bak PO Box 67 Irene, SD 57037-0067	Work Phone:	(605)263-3476
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	irenecityhall@iw.net
Financial Contact:	Ms Casey Van Beek PO Box 67 Irene, SD 57037-0067	Work Phone:	(605)263-3476
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	irenecityhall@iw.net
Other Contacts:	Mayor Bryce Johnke PO Box 67 Irene, SD 57037-0067	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	June 1, 2024	Area Served:	Clay, Turner, Yankton County
Type of System:	Community	Contract Laboratory:	Sioux Falls Health Laboratory
Service Connections:	220	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	BY Water District (0865)		

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 24, 2023</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2026</u>
E	Lead - 90% Level	<u>0.5</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.025</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Last Qtr Cl Residual:	<u>2.43</u> mg/l
D	Running Annual Average:	<u>2.51</u> mg/l
E	Date of last DBP test:	<u>September 15, 2025</u>
F	THM - Qtr Average:	<u>46</u> ug/l
G	Haa5 - Qtr Average:	<u>17.4</u> ug/l

Asbestos

A	Date of last test:	<u></u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Irene

EPA ID: 0173

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected