

Town of Lesterville Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)

Population Served:	115	System Population:	115
Certified Operator:	Mr Paul Scherschligt PO Box 36 Lesterville, SD 57040-0036	Work Phone:	(605)364-7793
		Home Phone:	(605)364-7415
		Cell Phone:	
		Fax:	(605)364-7588
		Email:	paul@yanktonoem.com
Financial Contact:	Ms Janelle Munkvold PO Box 36 Lesterville, SD 57040-0036	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	lestsd@gwtc.net
Other Contacts:	President Trevor Munkvold PO Box 36 Lesterville, SD 57040-0036	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	June 6, 2023	Area Served:	Yankton County
Type of System:	Community	Contract Laboratory:	Sioux Falls Health Laboratory
Service Connections:	90	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	BY Water District (0865)		

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 26, 2023</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2026</u>
E	Lead - 90% Level	<u>0.415</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.04</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Last Qtr Cl Residual:	<u>2</u> mg/l
D	Running Annual Average:	<u>2.01</u> mg/l
E	Date of last DBP test:	<u>September 24, 2025</u>
F	THM - Qtr Average:	<u>51</u> ug/l
G	Haa5 - Qtr Average:	<u>19.7</u> ug/l

Asbestos

A	Date of last test:	
B	Asbestos Result:	million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Lesterville

EPA ID: 0195

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
FTM-Routine Samples	RTCR	11/01/2024	Public Notice Requested
	RTCR		Compliance Achieved
FTM-Routine Samples	RTCR	08/01/2024	Public Notice Requested
	RTCR		Compliance Achieved
	RTCR		Compliance Achieved
FTM-Routine Samples	RTCR	05/01/2024	Public Notice Requested
	RTCR		Compliance Achieved
FTM-Routine Samples	RTCR	11/01/2023	Public Notice Requested
	RTCR		Compliance Achieved
	RTCR		Public Notice Received
DBP Failure To Monitor	Chlorine	07/01/2022	Public Notice Requested
	Chlorine		Compliance Achieved
FTM-Routine Samples	RTCR	08/01/2022	Public Notice Requested
	RTCR		Compliance Achieved
	RTCR		Public Notice Received
FTM-Routine Samples	RTCR	05/01/2022	Public Notice Requested
	RTCR		Compliance Achieved
DBP Failure To Monitor	Chlorine	07/01/2021	Public Notice Requested
	Chlorine		Public Notice Received
	Chlorine		Compliance Achieved
FTM-Routine Samples	RTCR	08/01/2021	Public Notice Requested
	RTCR		Compliance Achieved
	RTCR		Public Notice Received

Significant Deficiency	Date Identified	Date Corrected