

City of McLaughlin Drinking Water Information

(General Information and Sampling Requirements as of April 10, 2024)



Secretary Award For Drinking Water Excellence

Population Served:	569	System Population:	569
Certified Operator:	Mr Nate Thompson PO Box 169 McLaughlin, SD 57642-0169	Work Phone:	(605)823-4428
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	nathanthompson@mclaughlinsd.city
Financial Contact:	Ms Jaycee Gehring PO Box 169 McLaughlin, SD 57642-0169	Work Phone:	(605)823-4428
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	jayceegehring@mclaughlinsd.city
Other Contacts:	Mayor David Wutzke PO Box 169 McLaughlin, SD 57642-0169	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	September 6, 2023	Area Served:	Corson County
Type of System:	Community	Contract Laboratory:	State Health Lab, Pierre
Service Connections:	297	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	Federal		

Bacteriological Monitoring

Bacteriological sampling and analysis: April 1, 2023 to April 1, 2024

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>June 16, 2020</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Annually</u>
D	Date Due Next	<u>2021</u>
E	Lead - 90% Level	<u>0.3</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: April 1, 2023 to April 1, 2024

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Last Qtr CI Residual:	<u>2.1</u> mg/l
D	Running Annual Average:	<u>1.99</u> mg/l
E	Date of last DBP test:	<u>August 30, 2023</u>
F	THM - Qtr Average:	<u>20.2</u> ug/l
G	Haa5 - Qtr Average:	<u>14.1</u> ug/l

Asbestos

A	Date of last test:	<u></u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of McLaughlin

EPA ID: 0198

Violations From **April 1, 2019** To **April 1, 2024**

Violation Type	Parameter	Date	Status
Follow-up Tap Sample Monitoring Violation	Lead/Copper	10/01/2023	Public Notice Requested

Significant Deficiency	Date Identified	Date Corrected