

Town of Oelrichs Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



2024 Certificate of Achievement Award.

| | | | |
|------------------------------|--|-----------------------------|------------------------------|
| Population Served: | 117 | System Population: | 117 |
| Certified Operator: | Mr Roy Merdanian PO Box 32 Oelrichs, SD 57763 | Work Phone: | |
| | | Home Phone: | |
| | | Cell Phone: | |
| | | Fax: | |
| | | Email: | merdanian3@gmail.com |
| Financial Contact: | Ms Ellen White PO Box 32 Oelrichs, SD 57763-0033 | Work Phone: | |
| | | Home Phone: | |
| | | Cell Phone: | |
| | | Fax: | |
| | | Email: | townfoelrichs@goldenwest.net |
| Other Contacts: | President Joe Messinio PO Box 32 Oelrichs, SD 57763-0032 | Work Phone: | |
| | | Home Phone: | (605)535-2214 |
| | | Cell Phone: | |
| | | Fax: | |
| | | Email: | |
| Last Inspection: | March 28, 2024 | Area Served: | Fall River County |
| Type of System: | Community | Contract Laboratory: | Midcontinent Laboratory |
| Service Connections: | 75 | Contamination Risk: | low |
| PWS Owner Type: | Local Government | Service Area: | Municipality |
| Water Purchased From: | Fall River WUD (2201) | | |

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

| | | |
|---|----------------------|----------------------------|
| A | Samples submitted: | <u>12</u> |
| B | Samples required: | <u>One Sample Monthly.</u> |
| C | Survey samples: | <u>0</u> |
| D | Safe samples: | <u>12</u> |
| E | Unsafe samples: | <u>0</u> |
| F | Repeat samples: | <u>0</u> |
| H | Groundwater Samples: | <u></u> |

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

| | | |
|---|--------------------|--------------------------------------|
| A | Date Last Tested: | <u>August 8, 2023</u> |
| B | Samples required: | <u>5</u> |
| C | Sampling Frequency | <u>Triennially</u> |
| D | Date Due Next | <u>2026</u> |
| E | Lead - 90% Level | <u>1.5</u> Action Level - 15 ug/l |
| F | Copper 90% Level | <u>0.105</u> Action Level - 1.3 mg/l |

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

| | | |
|---|-------------------------|----------------------------|
| A | Samples submitted: | <u>12</u> |
| B | Samples required: | <u>One Sample Monthly.</u> |
| C | Last Qtr Cl Residual: | <u>0.78</u> mg/l |
| D | Running Annual Average: | <u>0.67</u> mg/l |
| E | Date of last DBP test: | <u>August 17, 2023</u> |
| F | THM - Qtr Average: | <u>14</u> ug/l |
| G | Haa5 - Qtr Average: | <u>0</u> ug/l |

Asbestos

| | | |
|---|--------------------|----------------------------------|
| A | Date of last test: | <u></u> |
| B | Asbestos Result: | <u></u> million fibers per liter |

Comments

Violations and Significant Deficiencies

Town of Oelrichs

EPA ID: 0230

Violations From October 1, 2020 To October 1, 2025

| Violation Type | Parameter | Date | Status |
|------------------------|-----------|------------|-------------------------|
| DBP Failure To Monitor | Chlorine | 10/01/2021 | Public Notice Requested |
| | Chlorine | | Public Notice Received |
| | Chlorine | | Compliance Achieved |
| FTM-Routine Samples | RTCR | 10/01/2021 | Public Notice Requested |
| | RTCR | | Compliance Achieved |
| | RTCR | | Public Notice Received |

| Significant Deficiency | Date Identified | Date Corrected |
|------------------------|-----------------|----------------|
| | | |
| | | |