City of Platte Drinking Water Information

(General Information and Sampling Requirements as of November 02, 2026)



2025 Certificate of Achievement Award.

Population Served: 1,256

System Population: 1,256

Certified Operator: Mr Richard Sternberg
PO Box 236
Platte, SD 57369-0862

Work Phone: (605)337-3921
Home Phone:
Cell Phone:
Fax: (605)337-3988
Email: plattefo@plattesd.org

Financial Contact: Ms Shauna Meyerink
PO Box 236
Platte, SD 57369-0236

Work Phone: (605)337-3921
Home Phone:
Cell Phone:
Fax:
Email: plattefo@plattesd.org

Other Contacts: Mayor Ken VanZee
PO Box 236
Platte, SD 57369-0236

Work Phone:
Home Phone:
Cell Phone:
Fax:
Email:

Last Inspection: October 29, 2025

Area Served: Charles Mix County

Type of System: Community

Contract Laboratory: State Health Lab, Pierre

Service Connections: 692

Contamination Risk: low

PWS Owner Type: Local Government

Service Area: Municipality

Water Purchased From: Randall Community Water District (0433)

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2025 to October 1, 2026

A	Samples submitted:	22
B	Samples required:	Two Samples Monthly.
C	Survey samples:	0
D	Safe samples:	22
E	Unsafe samples:	0
F	Repeat samples:	0
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	September 30, 2024	
B	Samples required:	10	
C	Sampling Frequency	Triennially	
D	Date Due Next	2027	
E	Lead - 90% Level	13.5	Action Level - 15 ug/l
F	Copper 90% Level	0.07	Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2025 to October 1, 2026

A	Samples submitted:	22	
B	Samples required:	Two Samples Monthly.	
C	Last Qtr Cl Residual:	2.65	mg/l
D	Running Annual Average:	2.53	mg/l
E	Date of last DBP test:	September 21, 2026	
F	THM - Qtr Average:	51.8	ug/l
G	Haa5 - Qtr Average:	21.4	ug/l

Asbestos

A	Date of last test:		
B	Asbestos Result:		million fibers per liter

Comments

Violations and Significant Deficiencies

City of Platte **EPA ID: 0246**

Violations From October 1, 2021 To October 1, 2026

Violation Type	Parameter	Date	Status
FTM-Routine Samples	RTCR	08/01/2026	Public Notice Requested
DBP Failure To Monitor	Trihalomethane (THM)	08/01/2023	Public Notice Requested
	Trihalomethane (THM)		Compliance Achieved
DBP Failure To Monitor	Haloacetic Acids (HAA5)	08/01/2023	Public Notice Requested
	Haloacetic Acids (HAA5)		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected