

Town of Trent Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



2024 Certificate of Achievement Award.

Population Served:	206	System Population:	206
Certified Operator:	Mr Greg Gross PO Box 754 - 403 East Third Street Trent, SD 57065	Work Phone: Home Phone: Cell Phone: Fax: Email:	 gregs_guns@msn.com
Financial Contact:	Ms Kim Nelson PO Box 754 Trent, SD 57065-0754	Work Phone: (605)428-5160 Home Phone: Cell Phone: Fax: Email:	 trenttown@siouxvalley.net
Other Contacts:	President Richard Nord PO Box 754 Trent, SD 57065-0754	Work Phone: Home Phone: Cell Phone: Fax: Email:	 trenttown@siouxvalley.net
Last Inspection:	November 19, 2024	Area Served:	Moody County
Type of System:	Community	Contract Laboratory:	Sioux Falls Health Laboratory
Service Connections:	112	Contamination Risk:	moderate
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	Big Sioux Community Water System (0429)		

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Monthly.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>12</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>September 10, 2024</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2027</u>
E Lead - 90% Level	<u>0.5</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Monthly.</u>
C Last Qtr Cl Residual:	<u>1.2</u> mg/l
D Running Annual Average:	<u>1.4</u> mg/l
E Date of last DBP test:	<u>September 17, 2024</u>
F THM - Qtr Average:	<u>23.1</u> ug/l
G Haa5 - Qtr Average:	<u>8.21</u> ug/l

Asbestos

A Date of last test:	<u></u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Trent

EPA ID: 0333

Violations From October 1, 2020 To October 1, 2025

Violation Type	Parameter	Date	Status
Follow-up Tap Sample Monitoring Violation	Lead/Copper	10/01/2021	Public Notice Requested
	Lead/Copper		Compliance Achieved
DBP Failure To Monitor	Haloacetic Acids (HAA5)	08/01/2021	Public Notice Requested
	Haloacetic Acids (HAA5)		Public Notice Received
	Haloacetic Acids (HAA5)		Compliance Achieved
DBP Failure To Monitor	Trihalomethane (THM)	08/01/2021	Public Notice Requested
	Trihalomethane (THM)		Public Notice Received
	Trihalomethane (THM)		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected