

Town of Utica Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



2024 Certificate of Achievement Award.

Population Served:	65	System Population:	65
Certified Operator:	Mr Chuck Flemming PO Box 78 Mission Hill, SD 57046	Work Phone: Home Phone: Cell Phone: Fax: Email:	 townofmissionhillmaintenance@gmail.com
Financial Contact:	Ms Theresa Holland PO Box 65 Utica, SD 57067-0065	Work Phone: Home Phone: Cell Phone: Fax: Email:	 townofutica@gmail.com
Other Contacts:	President Bryan Hubbard PO Box 65 Utica, SD 57067-0065	Work Phone: Home Phone: Cell Phone: Fax: Email:	 uticamayor@gmail.com
Last Inspection:	July 17, 2024	Area Served:	Yankton County
Type of System:	Community	Contract Laboratory:	Sioux Falls Health Laboratory
Service Connections:	36	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	BY Water District (0865)		

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 30, 2024</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2027</u>
E	Lead - 90% Level	<u>5.11</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.045</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Last Qtr Cl Residual:	<u>2.19</u> mg/l
D	Running Annual Average:	<u>2.22</u> mg/l
E	Date of last DBP test:	<u>September 24, 2025</u>
F	THM - Qtr Average:	<u>49.5</u> ug/l
G	Haa5 - Qtr Average:	<u>21.6</u> ug/l

Asbestos

A	Date of last test:	
B	Asbestos Result:	million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Utica

EPA ID: 0338

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	07/07/2025	Reminder Notice
Lack of Certified Operator	Certified Operator	09/15/2021	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected