

Town of Volin Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



Secretary Award For Drinking Water Excellence

Population Served:	161	System Population:	161
Certified Operator:	Mr Russell Frazier PO Box 131 Volin, SD 57072-0143	Work Phone: Home Phone: Cell Phone: Fax: (605)267-2991 Email: townofvolin@gmail.com	
Financial Contact:	Ms Amanda Frazier PO Box 175 Volin, SD 57072-0175	Work Phone: (605)267-0137 Home Phone: Cell Phone: Fax: Email: townofvolin@gmail.com	
Other Contacts:	President Corey Logan PO Box 175 Volin, SD 57072-0175	Work Phone: Home Phone: Cell Phone: Fax: Email:	
Last Inspection:	August 25, 2025	Area Served:	Yankton County
Type of System:	Community	Contract Laboratory:	State Health Lab, Pierre
Service Connections:	73	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	BY Water District (0865)		

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 30, 2024</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2027</u>
E	Lead - 90% Level	<u>6.35</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.04</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Last Qtr Cl Residual:	<u>2.63</u> mg/l
D	Running Annual Average:	<u>2.68</u> mg/l
E	Date of last DBP test:	<u>September 17, 2025</u>
F	THM - Qtr Average:	<u>52.1</u> ug/l
G	Haa5 - Qtr Average:	<u>18</u> ug/l

Asbestos

A	Date of last test:	
B	Asbestos Result:	million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Volin

EPA ID: 0347

Violations From

October 1, 2020

To

October 1, 2025

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected