

Town of Wallace Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)

Population Served:	91	System Population:	91
Certified Operator:	Mr Pat Callan PO Box 65 Wallace, SD 57272-0065	Work Phone: Home Phone: Cell Phone: Fax: Email:	 patcallan@hotmail.com
Financial Contact:	Mr Jillian Coumos PO Box 65 Wallace, SD 57272-0065	Work Phone: Home Phone: Cell Phone: Fax: Email:	 townofwallace@outlook.com
Other Contacts:	President Al Keller PO Box 65 Wallace, SD 57272-0065	Work Phone: Home Phone: Cell Phone: Fax: Email:	
Last Inspection:	November 22, 2024	Area Served:	Codington County
Type of System:	Community	Contract Laboratory:	State Health Lab, Pierre
Service Connections:	43	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	Clark Rural Water System (0881)		

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>15</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>14</u>
E	Unsafe samples:	<u>1</u>
F	Repeat samples:	<u>3</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 12, 2024</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2027</u>
E	Lead - 90% Level	<u>0.23</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>15</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Last Qtr Cl Residual:	<u>0.53</u> mg/l
D	Running Annual Average:	<u>0.7</u> mg/l
E	Date of last DBP test:	<u>September 26, 2024</u>
F	THM - Qtr Average:	<u>37.7</u> ug/l
G	Haa5 - Qtr Average:	<u>9.81</u> ug/l

Asbestos

A	Date of last test:	
B	Asbestos Result:	million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Wallace

EPA ID: 0350

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Chlorine	10/01/2024	Public Notice Requested
	Chlorine		Compliance Achieved
DBP Failure To Monitor	Chlorine	07/01/2024	Public Notice Requested
	Chlorine		Compliance Achieved
DBP Failure To Monitor	Chlorine	01/01/2024	Public Notice Requested
	Chlorine		Compliance Achieved
DBP Failure To Monitor	Chlorine	07/01/2023	Public Notice Requested
	Chlorine		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected