

City of Britton Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



2024 Certificate of Achievement Award.

Population Served:	1,215	System Population:	1,215
Certified Operator:	Mr Cameron Gerken 1523 Vander Horck Street Britton, SD 57430	Work Phone:	(605)448-5733
		Home Phone:	
		Cell Phone:	
		Fax:	(605)448-5721
		Email:	shop@brittonsd.net
Financial Contact:	Ms Jennifer Athey PO Box 126 Britton, SD 57430-0126	Work Phone:	(605)448-5721
		Home Phone:	
		Cell Phone:	
		Fax:	(605)448-5721
		Email:	financeofficer@brittonsd.net
Other Contacts:	Mayor Clyde Fredrickson PO Box 126 Britton, SD 57430-0126	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	October 25, 2023	Area Served:	Marshall County
Type of System:	Community	Contract Laboratory:	State Health Lab, Pierre
Service Connections:	673	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Municipality
Water Purchased From:	Brown-Day-Marshall RWS (0882)		

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A Samples submitted:	24
B Samples required:	Two Samples Monthly.
C Survey samples:	0
D Safe samples:	24
E Unsafe samples:	0
F Repeat samples:	0
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	August 28, 2024
B Samples required:	10
C Sampling Frequency	Triennially
D Date Due Next	2027
E Lead - 90% Level	2.3 Action Level - 15 ug/l
F Copper 90% Level	0.27 Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A Samples submitted:	24
B Samples required:	Two Samples Monthly.
C Last Qtr CI Residual:	2.73 mg/l
D Running Annual Average:	2.98 mg/l
E Date of last DBP test:	September 16, 2025
F THM - Qtr Average:	4.61 ug/l
G Haa5 - Qtr Average:	6.52 ug/l

Asbestos

A Date of last test:	September 5, 1995
B Asbestos Result:	0.167 million fibers per liter

Comments

[Large empty box for comments]

Violations and Significant Deficiencies

City of Britton

EPA ID: 0388

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Chlorine	01/01/2022	Public Notice Requested
	Chlorine		Public Notice Received
	Chlorine		Compliance Achieved
FTM-Routine Samples	RTCR	01/01/2022	Public Notice Requested
	RTCR		Public Notice Received
	RTCR		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected