

TM Rural Water District Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



Secretary Award For Drinking Water Excellence

Population Served:	10,860	System Population:	4,250
Certified Operator:	Mr Jay Jorgensen PO Box 445 Parker, SD 57053-0445	Work Phone:	(605)297-3334
		Home Phone:	
		Cell Phone:	
		Fax:	(605)297-3310
		Email:	tmrwd@tmruralwater.com
Financial Contact:	Mr Jay Jorgensen PO Box 445 Parker, SD 57053-0445	Work Phone:	(605)297-3334
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	tmrwd@tmruralwater.com
Other Contacts:	Mr Tom Kramer 6109 W 43rd Street Sioux Falls, SD 57106	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	tmrwd@tmruralwater.com
Last Inspection:	June 11, 2025	Area Served:	McCook, Turner County
Type of System:	Community	Contract Laboratory:	State Health Lab, Pierre
Service Connections:	1,700	Contamination Risk:	low
PWS Owner Type:	Local Government	Service Area:	Rural Water System/Colonies
Water Purchased From:	BY Water District (0865)		

Monitoring/Reporting - Entry Point

TM Rural Water District

EPA ID: 0999

SAMPLING

Entry point: New Water Treatment Plant

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Oct-22		
	B. Arsenic	Every nine years	Yes	Oct-22		
	C. Barium	Every nine years	Yes	Oct-22		
	D. Beryllium	Every nine years	Yes	Oct-22		
	E. Cadmium	Every nine years	Yes	Oct-22		
	F. Chromium	Every nine years	Yes	Oct-22		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Triennially	No	Oct-24		
	I. Mercury	Every nine years	Yes	Oct-22		
	J. Nickel	Every nine years	Yes	Oct-22		
	K. Selenium	Every nine years	Yes	Oct-22		
	L. Thallium	Every nine years	Yes	Oct-22		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals	Triennially	No	Nov-22		
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	*bad date*		
	B. Method 524	Triennially	No	*bad date*		
	C. Method 525	Triennially	No	*bad date*		
	D. Method 531.1	Triennially	No	*bad date*		
	E. Method 547	Triennially	No	*bad date*		
	F. Method 548	Triennially	No	*bad date*		
	G. Method 549	Triennially	No	*bad date*		
5	Nitrate	Annually	N/A	Apr-25		
6	Nitrite	Triennially	N/A	Apr-24		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>55</u>
B	Samples required:	<u>Five Samples Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>55</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 14, 2022</u>
B	Samples required:	<u>20</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2025</u>
E	Lead - 90% Level	<u>0.88</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.03</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>55</u>
B	Samples required:	<u>Five Samples Monthly.</u>
C	Last Qtr Cl Residual:	<u>2.76</u> mg/l
D	Running Annual Average:	<u>2.8</u> mg/l
E	Date of last DBP test:	<u>September 24, 2025</u>
F	THM - Qtr Average:	<u>33.7</u> ug/l
G	Haa5 - Qtr Average:	<u>19.7</u> ug/l

Asbestos

A	Date of last test:	<u></u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

TM Rural Water District

EPA ID: 0999

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected