

# Maxwell Colony Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)

**Population Served:** 150

**System Population:** 150

**Certified Operator:** Mr Jonas Wipf  
42805 Maxwell Road  
Scotland, SD 57059-7200

**Work Phone:**  
**Home Phone:**  
**Cell Phone:**  
**Fax:**  
**Email:** jonas@maxwellcolony.com

**Financial Contact:** Mr Mark Hofer  
42805 Maxwell Road  
Scotland, SD 57059

**Work Phone:** (605)583-2861  
**Home Phone:**  
**Cell Phone:**  
**Fax:**  
**Email:** maxwellc@gwtc.net

**Other Contacts:** Mr Jeff Sveen  
PO Box 490  
Aberdeen, SD 57402-0490

**Work Phone:**  
**Home Phone:**  
**Cell Phone:**  
**Fax:**  
**Email:**

**Last Inspection:** March 20, 2023

**Area Served:** Bon Homme County

**Type of System:** Community

**Contract Laboratory:** Sioux Falls Health Laboratory

**Service Connections:** 34

**Contamination Risk:** low

**PWS Owner Type:** Private Ownership

**Service Area:** Housing Development

**Water Produced And Used By The Maxwell Colony Public Water System**

# Monitoring/Reporting - Entry Point

**Maxwell Colony**

**EPA ID: 2023**

## SAMPLING

Entry point: #1 - Turkey Well

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Mar-22		
	B. Arsenic	Every nine years	Yes	Mar-22		
	C. Barium	Every nine years	Yes	Mar-22		
	D. Beryllium	Every nine years	Yes	Mar-22		
	E. Cadmium	Every nine years	Yes	Mar-22		
	F. Chromium	Every nine years	Yes	Mar-22		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Mar-22		
	I. Mercury	Every nine years	Yes	Mar-22		
	J. Nickel	Every nine years	Yes	Mar-22		
	K. Selenium	Every nine years	Yes	Mar-22		
	L. Thallium	Every nine years	Yes	Mar-22		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals	Triennially	No	Aug-25		
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	May-98		
	B. Method 524	Triennially	No	Apr-98		
	C. Method 525	Triennially	No	Jun-98		
	D. Method 531.1	Triennially	No	Apr-98		
	E. Method 547	Triennially	No	Apr-98		
	F. Method 548	Triennially	No	Apr-98		
	G. Method 549	Triennially	No	Apr-98		
5	Nitrate	Annually	N/A	Jun-25		
6	Nitrite	Triennially	N/A	Jun-25		

(These values are calculated from available data. Check correspondence for verification.)

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>July 12, 2022</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2025</u>
E	Lead - 90% Level	<u>0.1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis:  to

A	Samples submitted:	<u>No Tests</u>
B	Samples required:	<u></u>
C	Last Qtr Cl Residual:	<u></u> mg/l
D	Running Annual Average:	<u></u> mg/l
E	Date of last DBP test:	<u>No Tests</u>
F	THM - Qtr Average:	<u></u> ug/l
G	Haa5 - Qtr Average:	<u></u> ug/l

### Asbestos

A	Date of last test:	<u></u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

Maxwell Colony

EPA ID: 2023

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
FTM-Routine Samples	RTCR	07/01/2025	Public Notice Requested
Lack of Certified Operator	Certified Operator	11/29/2023	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected