

Rimrock Water Company LLC Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



2024 Certificate of Achievement Award.

Population Served: 688

System Population: 365

Certified Operator: Ms Victoria Dungey
189 State Hwy 111
Aladdin, WY 82710

Work Phone: (605)892-5640
Home Phone:
Cell Phone:
Fax:
Email: vdungey@outlook.com

Financial Contact: Mr Dusty Morehead
12312 Stampede Road
Whitewood, SD 57793

Work Phone:
Home Phone:
Cell Phone:
Fax:
Email: dustymorehead@gmail.com

Other Contacts: Mr Scott Reder
18917 Danish Road
Fruitdale, SD 57717

Work Phone:
Home Phone:
Cell Phone:
Fax:
Email: scottr@pioneerbankandtrust.com

Last Inspection: April 3, 2024

Area Served: Butte County

Type of System: Community

Contract Laboratory: Midcontinent Laboratory

Service Connections: 146

Contamination Risk: low

PWS Owner Type: Private Ownership

Service Area: Housing Development

Water Sold To: Hay Creek Water Company, Red Water Distribution LLC

Monitoring/Reporting - Entry Point

Rimrock Water Company LLC

EPA ID: 2220

SAMPLING

Entry point: Treat Site - Red Water Well

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Jul-22		
	B. Arsenic	Every nine years	Yes	Jul-22		
	C. Barium	Every nine years	Yes	Jul-22		
	D. Beryllium	Every nine years	Yes	Jul-22		
	E. Cadmium	Every nine years	Yes	Jul-22		
	F. Chromium	Every nine years	Yes	Jul-22		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride		No			This system fluoridates
	I. Mercury	Every nine years	Yes	Jul-22		
	J. Nickel	Every nine years	Yes	Jul-22		
	K. Selenium	Every nine years	Yes	Jul-22		
	L. Thallium	Every nine years	Yes	Jul-22		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals	Quarterly	No			No Sampling Data
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	*bad date*		
	B. Method 524	Triennially	No	*bad date*		
	C. Method 525	Triennially	No	*bad date*		
	D. Method 531.1	Triennially	No	*bad date*		
	E. Method 547	Triennially	No	*bad date*		
	F. Method 548	Triennially	No	*bad date*		
	G. Method 549	Triennially	No	*bad date*		
5	Nitrate	Annually	N/A	Jan-24		
6	Nitrite	Triennially	N/A	Jan-24		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 28, 2022</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2025</u>
E	Lead - 90% Level	<u>1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.01</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Last Qtr Cl Residual:	<u>0.83</u> mg/l
D	Running Annual Average:	<u>0.86</u> mg/l
E	Date of last DBP test:	<u>September 22, 2025</u>
F	THM - Qtr Average:	<u>4.79</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A	Date of last test:	<u></u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Rimrock Water Company LLC

EPA ID: 2220

Violations From October 1, 2020 To October 1, 2025

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Chlorine	10/01/2022	Public Notice Requested
	Chlorine		Compliance Achieved
FTM-Routine Samples	RTCR	10/01/2022	Public Notice Requested
	RTCR		Compliance Achieved
	RTCR		Public Notice Received
DBP Failure To Monitor	Trihalomethane (THM)	08/01/2022	Public Notice Requested
DBP Failure To Monitor	Haloacetic Acids (HAA5)	08/01/2022	Public Notice Requested

Significant Deficiency	Date Identified	Date Corrected