

# North Brookings Water and Sanitary District Drinking Water Information

(General Information and Sampling Requirements as of October 24, 2025)



## 2024 Certificate of Achievement Award.

<b>Population Served:</b>	48	<b>System Population:</b>	48
<b>Certified Operator:</b>	Mr Dave Felton 3009 Sunnyview Drive Brookings, SD 57006	<b>Work Phone:</b>	
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	dfelton1952@yahoo.com
<b>Financial Contact:</b>	Mr Jim Lambertz 1227 30th St Brookings, SD 57006	<b>Work Phone:</b>	
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	lambertz@itctel.com
<b>Other Contacts:</b>			
<b>Last Inspection:</b>	May 24, 2024	<b>Area Served:</b>	Brookings County
<b>Type of System:</b>	Community	<b>Contract Laboratory:</b>	State Health Lab, Pierre
<b>Service Connections:</b>	21	<b>Contamination Risk:</b>	low
<b>PWS Owner Type:</b>	Private Ownership	<b>Service Area:</b>	Sanitary Improvement District
<b>Water Purchased From:</b>	Brookings Municipal Utilities (0071)		

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 1, 2023</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2025</u>
E	Lead - 90% Level	<u>6.3</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.04</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2024 to October 1, 2025

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Monthly.</u>
C	Last Qtr Cl Residual:	<u>2.37</u> mg/l
D	Running Annual Average:	<u>2.4</u> mg/l
E	Date of last DBP test:	<u>September 10, 2025</u>
F	THM - Qtr Average:	<u>42.7</u> ug/l
G	Haa5 - Qtr Average:	<u>16.9</u> ug/l

### Asbestos

A	Date of last test:	<u>December 2, 2020</u>
B	Asbestos Result:	<u>ND</u> million fibers per liter

Comments

# Violations and Significant Deficiencies

North Brookings Water and Sanitary District

EPA ID: 2377

Violations From **October 1, 2020** To **October 1, 2025**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected