

Common Test Results For The Town of Brentford (EPA ID: 0065)

Sampler- Mr Ryan Remily Work Phone-(605)380-5547
Title- Utilities Manager
Address- PO Box 103
 Brentford SD 57429-0071

Location- City: Brentford County: Spink
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 88 Service Connections- 25

Sources for Brentford

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
02	EAST	1974	1120	2		Groundwater	Non-Vulnerable	No Treatment
03	WEB RWS				Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

Common Test Results For The Town of Brentford (EPA ID: 0065)

Test Data
(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	06/20/88	2205	3094	8.24	216	0	735	8.5	16.3	4.2	0.20	0.09	192.0	1085	264	0	58	-0.10	0.1	2.54