

Common Test Results For The Town of Raymond (EPA ID: 0276)

Sampler- Mr Darrin Leetch Work Phone-(605)532-5942
Title- Utilities Manager
Address- PO Box 72
Raymond SD 57258-0072

Location- City: Raymond County: Clark
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Groundwater Supply

Population Served- 53 Service Connections- 42

Sources for Raymond

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
03	CLARK RWS	0000	0000	0000	Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

Common Test Results For The Town of Raymond (EPA ID: 0276)

Test Data
(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	12/12/84	2045	3392	6.90	366	0	759	10.6	6.5	2.5	0.67	0.57	225.0	950	447	0	26	-1.55	2.0	5.07
02	Treated	02/17/87	2191	3240	8.07	370	0	780	8.7	6.9	2.2	0.34	0.06	213.0	983	451	0	26	-0.41	2.2	5.38
Averages			2118	3316	7.49	368	0	770	9.7	6.7	2.4	0.51	0.32	219.0	967	449	0	26		2.1	5.23