

Common Test Results For Rendezvous Ranch (EPA ID: 2210)

Sampler- Mr Dylan Striebel Work Phone-(605)786-4366
Title- Clearwater Consultin
Address- PO Box 761
 Black Hawk SD 57718

Location- City: Rapid City County: Lawrence
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 195 Service Connections- 78

Sources for Rendezvous Ranch

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1976	806	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	2000	1180	5	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
03	TREAT SITE - #1/#2				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites

Common Test Results For Rendezvous Ranch (EPA ID: 2210)

Test Data
(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	03/06/01	293	521	7.78	254	0	8	2.2	50.0	30.3	0.28	0.05	1.0	18	310	0	250	+0.58	0.2	0.34
02	Treated	03/06/01	292	528	7.77	253	0	6	2.7	50.9	32.2	0.05	0.05	1.5	18	309	0	260	+0.57	0.2	0.37
03	Treated	01/13/04	289	526	7.89	254	0	3	1.8	53.7	46.7	0.05	0.05	5.5	23	310	0	326	+0.52	0.5	0.33
03	Treated	10/05/06	264	529	7.90	255	0	3	2.3	54.9	31.6	0.05	0.01	1.3	33	312	0	267	+0.54	0.2	0.33
03	Treated	05/20/13	273	525	7.70	256	0	3	2.5	62.7	32.3	0.05	0.01	1.0	31	312	0	289	+0.40	0.2	0.34
03	Treated	03/11/19	268	525	8.19	259	0	5	1.7	60.6	27.2	0.00	0.00	4.9	23	315	0	264	+0.88	0.0	0.30
Averages			280	526	7.87	255	0	5	2.2	55.5	33.4	0.08	0.03	2.5	24	311	0	276		0.2	0.33