


## SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT

10-85

Location NW 1/4 NE 1/4 Sec 28 Twp R6 Rg 51

County Roberts

Please mark well location with an "X"



Well Owner:

Name Ottertail Power Co.

Address 215 South Cascade

Fergus Falls MN 56537

Plugging completion Date 12/1/06

## CHECK APPROPRIATE BOX

EXISTING WELL



TEST HOLE



Well depth

13'

Casing material

PVC

Casing size(s)

2"

Casing condition

Good

Hole depth

Hole size

Describe plugging procedure:

Removed protector pipe - Pumped Bentonite Grout  
From Bottom to Top of well - Cut well flush with grade

Describe grout or plugging material:

Bentonite Grout

Type of non-slip plug:

This well or test hole was plugged under license # 584 And this report is true and accurate.

Drilling firm

Vickers well drilling

Signature of Licensed Representative

[Signature]

Signature of Well Owner

[Signature] Agent WCEC

Date

1/9/07

RECEIVED

JAN 22 2007

WATER RIGHTS PROGRAM

1-22-07