


SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02

Location $\frac{1}{4}$ $\frac{1}{4}$ Sec 14 Twp 4S Rg 19ECounty JacksonLot 4

North

Please mark well
location with an "X"

Well Completion Date

12/21/10

 Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?
 ft. from ALL CLEAR (identify source)

PROPOSED USE:

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING:

AUGER BUCKET

CASING DATA:

☐ Steel ☒ Plastic ☐ Other

If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
LB/FT	16.00 IN	0.0 FT	21.0 FT	36.00 IN
LB/FT	16.00 IN	21.0 FT	40.0 FT	36.00 IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
BENTONITE	21	27.0 Lb/gal	13.0 Ft	6.0 Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

SCREEN:

☐ Perforated pipe ☐ Manufactured
Diameter 16.00 Inches Length 19.0 FeetMaterial PVC PLASTIC WATER WELL CASINGSlot Size .020 Set From 21.0 Feet to 40.0 Feet

Other information

WAS A PACKER OR SEAL USED?

☐ Yes ☒ No

If so, what material?

Describe packer(s) and location

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? WELL CHOLORINE

 Lab to which water
 quality sample sent for analysis
Well Owner: NORMAN AMIOTTE

Business Name:

Address: P.O. BOX 7City, State, Zip: Interior SD 57750

WELL LOG:

FORMATION	DEPTH	
	FROM	TO
TOPSOIL	0	1
LIGHT SAND	1	13
DAMP SAND	13	17
COURSE SAND/PEA ROCK	17	19
BADLANDS	19	40

STATIC WATER LEVEL 17.0 FEET

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ Inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced flow rate _____ GPM

Can well be completely shut in?

WELL TEST DATA:

☐ Pumped Describe: APPROXIMATELY 3-5 GPM
☒ Bailed☐ Other

Pumping Level Below Land Surface

_____ Ft. After _____ Hrs. pumped _____ GPM

_____ Ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate: _____ GPM

REMARKS

RECEIVED

JAN 10 2011

WATER RIGHTS
PROGRAMThis well was drilled under license # 195 and this report is true and accurate.Drilling firm: B & B FOUNDATION SERVICE, INC.

Signature of License Representative:

Signature of Well Owner or Equitable Property Holder:

Date: Jan. 6 - 2011