


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02Location NW 1/4 NE 1/4 Sec 34 Twp 7S Rg 7E

Well Owner:

County Fall RiverPlease mark well
location with an "X"

Oral SD
57766

Name: CP RailAddress: 501 Marquette Avenue South #1525City, State, Zip: Minneapolis MN 55402

Comments:

CP Rail - Richard JohnstonPlugging Completion Date July 21, 2010**CHECK APPROPRIATE BOX**EXISTING WELL ☐TEST HOLE ☒

Well depth _____

Casing material _____

Casing size(s) _____

Casing condition _____

Hole depth 8 boring all 11 feetHole size 2"MacroCoresampler

Describe plugging procedure:

tremi Pumped High Solids bentonite Grout to bottom of drilled boring/temp monitoring well.
Soils brown Silty clay to sandy clay, with seams of sand & gravel.


Describe grout or plugging material:

Wyo-Ben High Solids Bentonite GroutType of non-slip plug: noneThis well or test hole was plugged under license # 615 and this report is true and accurate.Drilling firm: AECOMSignature of Licensed Representative: [Signature]

Signature of Well Owner: _____

Date: 1-10-2011**RECEIVED****JAN 13 2011****WATER RIGHTS
PROGRAM**

1-18-11



RECEIVED
JAN 13 2011
WATER RIGHTS
PROGRAM

AECOM

Canadian Pacific Oral, SD Project # 60150289		Boring Locations
DATE: 12/29/10	DRWN: T.C./STP	