


SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02

Location SE 1/4 SE 1/4 Sec 1 Twp 3N Rg 8ECounty Meade

North

Please mark well
location with an "X"

Well Completion Date

2/14/11

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?
ft. from all clear (identify source)

PROPOSED USE:

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING:

auger bucket

CASING DATA:

☐ Steel ☒ Plastic ☐ Other

If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
LB/FT	<u>16.00</u> IN	<u>0.0</u> FT	<u>6.0</u> FT	<u>36.00</u> IN
LB/FT	<u>6.00</u> IN	FT	<u>40.0</u> FT	<u>36.00</u> IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
		Lb/gal	Ft	Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

SCREEN:

☒ Perforated pipe ☐ Manufactured
Diameter 16.00 Inches Length 34.0 FeetMaterial Schedule 40 PVC Plastic PipeSlot Size .020 Set From 6.0 Feet to 40.0 Feet

Other information

WAS A PACKER OR SEAL USED?

☐ Yes ☒ No

If so, what material?

Describe packer(s) and location

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? well chlorine
☐ No, Why Not?
Lab to which water
quality sample sent for analysisWell Owner: Ron Johnson

Business Name:

Address: P.O. Box 22City, State, Zip: Caputa SD 57725

WELL LOG:

FORMATION	DEPTH	
	FROM	TO
Topsoil	0	1
Clay with cobbles	1	4
Light cobbles with sand	4	12
Shale	12	40

STATIC WATER LEVEL 5.0 FEET

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ Inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced flow rate _____ GPM

Can well be completely shut in?

WELL TEST DATA:

☒ Pumped Describe: 50 gallons per minute
☐ Bailed

☐ Other

Pumping Level Below Land Surface

_____ Ft. After _____ Hrs. pumped _____ GPM

_____ Ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate: _____ GPM

REMARKS
good well

RECEIVED

FEB 24 2011

WATER RIGHTS
PROGRAMThis well was drilled under license # 195 and this
report is true and accurate.Drilling firm: B & B Foundation Service, Inc.

Signature of License Representative:

Signature of Well Owner or Equitable Property Holder:

Date: 2-17-11

2-24-11