SOUTH DAKOTA WATER WELL COMPLETION REPORT

10-85

Location NW ¼ SW ¼ Sec 25 Twp 128 ~~129~~ Rg 49 W R

County Roberts County
Victor Twnsp

Please mark well location with an "X"



Well Completion Date 10/9/90

PROPOSED USE:
☑ Domestic ☐ Municipal ☐ Test Holes
☐ Irrigation ☐ Industrial ☐ Stock

Method of Drilling:
Rotary

CASING DATA:
☐ Steel ☑ Plastic ☐ Other
If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
LB/FT	5 IN	0 FT	65 FT	9 IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUT:
Was the well grouted? ☑ YES ☐ NO
To what depth? 26 FEET
What is grouting material? neat cement
If cement, number of sacks?
Describe grouting procedure

What was grout weight? 15 LB/GAL

SCREEN: ☐ Perforated pipe ☑ Manufactured
Diameter 5 IN Length 10' FEET
Material pvc
Slot Size 015 Set From 50 Feet To 65 Feet
Slot Size Set From Feet To Feet
Slot Size Set From Feet To Feet
Other information

Was a packer or seal used? ☐ YES ☑ NO
If so, what naterial?
Describe packer(s) and location? pvc coupling on 5" pvc screen w/cap

Was well disinfected upon completion? ☑ YES ☐ NO
Explain HH WATER
Bacteriological analysis ☐ YES ☐ NO
Laboratory sent to

Well Owner:
Name Lary Braun
Address Roshott SD
Well Log: Depth 65'

Formation	From	To
Black soil	0	1
Yellow clay	1	22
Hard Grey clay	22	26
fine Greysand	26	65

STATIC WATER LEVEL 18' Feet
If flowing: closed in pressure PSI
GPM flow through inch pipe
Controlled by ☐ Valve ☐ Reducers ☐ Other
If other; specify
Can well be completely shut in?

WELL TEST DATA:
☑ Pumped ½hp sub pump
☐ Bailed Describe:
☐ Other

Pumping Level Below Land Surface
50 ft. After 12 Hrs. pumped ~~[illegible]~~ 15 GPM
ft. After Hrs. pumped GPM
ft. After Hrs. pumped GPM

REMARKS:

This well was drilled under license # 78083
And this report is true and accurate.
Drilling firm Whaley Well Drilling, Inc
Signature of License Representative:
Ron Whaley
Signature of Well Owner:

JAN 1991
DIVISION OF WATER RIGHTS
Pierre, SD

Date 12/28/90
1-29-91