

SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT

10-85

Location $\frac{1}{4}$ $\frac{1}{4}$ Sec. 8 Twp. Scotland 96-58

Well Owner:

County

Box Home

Name

City of Scotland

Address

P.O. Box 309Scotland S.D.


Plugging completion

Date July 2, 1992

Please mark well location with an "X"

W

E



1 mile

Well No. 3

CHECK APPROPRIATE BOX

EXISTING WELL



TEST HOLE



Well depth

160 ft.

Casing material

Steel

Casing size(s)


8 inch

Casing condition

Unknown

Hole depth

Hole size



Describe plugging procedure:

42 bags of cement were pumped down the well at 15 pounds per gallon

Describe grout or plugging material:

Cement

Type of non-slip plug:

Grout

This well or test hole was plugged under license #

302

And this report is true and accurate.

Drilling firm

Lehu Well Drilling

Signature of Licensed Representative

Victor Lehu

Signature of Well Owner

James S. Clark

Date

7-14-92