


STATE OF SOUTH DAKOTA WELL DRILLERS REPORT

Location 1/4 NE 1/4 Sec 33 Twp 124 Rg 63County Brown

Please mark well location with an "X"

Well Completion Date 5-7-91

PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Test Holes
☒ Irrigation ☐ Industrial ☐ Stock

Method of Drilling:

Forward rotary

WELL CONSTRUCTION:

Diameter of hole 8 inches Depth 34 feetCasing: ☐ Steel ☒ Plastic ☐ Other
Specify _____
 Pipe Weight Diameter From To
200 lb/ft 5 inches 0 feet 24 feet
 _____ lb/ft _____ inches _____ feet _____ feet
Was a well screen used? ☒ Yes ☐ No

If Not Specify _____

Screen Type plastic Slot Size 20"Length 10 Diameter 5"Was Casing left open end? ☐ Yes ☒ NoWas a Packer or seal used? ☐ Yes ☒ No

If so what material? _____

Was well gravel packed? ☒ Yes ☐ NoWas well grouted? ☒ Yes ☐ NoDescribe grouting procedure turnipTo what depth? 20 FeetWhat was grouting material? cement

If cement, how many sacks? _____

Location of packer(s) and screen or perforated pipe _____

 WAS WELL PLUGGED OR ABANDONED ☐ Yes ☒ No
 If so how and with what material? _____

Well Owner:

Name Ron PfeifferAddress 302 S 2 Aberdeen, SDWell Log: Depth 57401

Formation	From	To
<u>topsoil</u>	<u>0</u>	<u>3</u>
<u>clay</u>	<u>3</u>	<u>7</u>
<u>sand</u>	<u>7</u>	<u>10</u>
<u>clay</u>	<u>10</u>	<u>20</u>
<u>sand fine dirty</u>	<u>20</u>	<u>35</u>

STATIC WATER LEVEL 13 1/2

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other

If other; specify _____

Can well be completely shut off? _____

WELL TEST DATA:

☒ Pumped _____☒ Bailed Describe: _____☐ Other _____

Pumping Level Below Land Surface

20 1/2 ft. After 4 Hrs. pumped 15 GPM

_____ ft. After _____ Hrs. pumped _____ GPM

_____ ft. After _____ Hrs. pumped _____ GPM

Remarks:

This well was drilled under license # 288

and this report is true and accurate.

Olson Well Drilling
 Drilling Firm Signed by Reg Olson
6-3-91
 Date