


STATE OF SOUTH DAKOTA WELL DRILLERS REPORT

Location NE 1/4 NW 1/4 Sec 12 Twp 128 Rg 75

County

CAMPBELL

Please mark well location with an "X"



Well Completion Date 10-13-88

PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Test Holes
☒ Irrigation ☐ Industrial ☐ Stock

Method of Drilling:

Rotary Drilling

WELL CONSTRUCTION:

Diameter of hole 24 inches Depth 52 feet

Casing: ☐ Steel ☐ Plastic ☐ Other

Specify Concrete

Pipe Weight Diameter From To

1 lb/ft 18 inches 0 feet 52 feet

1 lb/ft 18 inches 0 feet 52 feet

Was a well screen used? ☐ Yes ☒ No

If Not Specify

Screen Type Slot Size

Length Diameter

Was Casing left open end? ☒ Yes ☐ No

Was a Packer or seal used? ☐ Yes ☐ No

If so what material?

Was well gravel packed? ☒ Yes ☐ No

Was well grouted? ☐ Yes ☒ No

Describe grouting procedure

2 1/2' above ground clay dark

To what depth? 2 Feet

What was grouting material? CLAY

If cement, how many sacks?

Location of packer(s) and screen or perforated pipe

WAS WELL PLUGGED OR ABANDONED ☐ Yes ☒ No

If so how and with what material?

STILL IN USE

Well Owner:

Name ALFRED BENZ

Address Artas, South Dakota

Well Log:

Depth

Formation

From

To

TOP SOIL

0

6

CLAY DARK


6

17

SHALE

17

52



STATIC WATER LEVEL 14 Feet

If flowing: closed in pressure PSI

GPM flow through inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other

If other; specify

Can well be completely shut off?

WELL TEST DATA:

☐ Pumped

☐ Bailed

Describe:

☐ Other

Pumping Level Below Land Surface

 ft. After Hrs. pumped GPM

 ft. After Hrs. pumped GPM

 ft. After Hrs. pumped GPM

Remarks:

WELL BETWEEN HILLS

ABOUT 160' FROM YARD

This well was drilled under license # 283

and this report is true and accurate.

ALBRECHT WELL Leonard Albrecht
 Drilling Firm Signed by

1-26-89
 Date

2-23-89