


Location S&E 17 Top 118 Ng 57County CLARK

Please mark well location with an "X"

Well Completion Date AUG - 8 - 91

## PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Test Holes  
☐ Irrigation ☐ Industrial ☒ Stock

## Method of Drilling:

Rotary

## CASING DATA:

☐ Steel ☒ Plastic ☐ Other

If other describe \_\_\_\_\_

| PIPEWEIGHT       | DIAMETER    | FROM        | TO            | HOLE DIAMETER |
|------------------|-------------|-------------|---------------|---------------|
| <u>2.2 LB/FT</u> | <u>4 IN</u> | <u>0 FT</u> | <u>383 FT</u> | <u>7 IN</u>   |
| _____ LB/FT      | _____ IN    | _____ FT    | _____ FT      | _____ IN      |
| _____ LB/FT      | _____ IN    | _____ FT    | _____ FT      | _____ IN      |
| _____ LB/FT      | _____ IN    | _____ FT    | _____ FT      | _____ IN      |

## GROUT:

Was the well grouted? ☐ YES ☐ NOTo what depth? 380 FEETWhat is grouting material? CementIf cement, number of sacks? 38Describe grouting procedure Pump down 1 inch  
Pipe out side of casingWhat was grout weight? 1 Gall Water to 1 Bag LB/GALSCREEN: ☐ Perforated pipe ☒ ManufacturedDiameter 4 IN Length 20 FEETMaterial PlasticSlot Size 10 Set From 383 Feet To 403 Feet

Slot Size \_\_\_\_\_ Set From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

Slot Size \_\_\_\_\_ Set From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

Other information \_\_\_\_\_

Was a packer or seal used? ☐ YES ☒ NO

If so, what material? \_\_\_\_\_

Describe packer(s) and location? \_\_\_\_\_

Was well disinfected upon completion? ☒ YES ☐ NOExplain Back Flush With ChlorineBacteriological analysis ☒ YES ☐ NO OKLaboratory sent to ITT Health Lab Pierre

## Well Owner:


Name LARRY DUNLUVAddress CLARK

Well Log:

Formation

Depth 408

From To

Yellow Clay 0 40Dark Blue 40 330Light Blue 330 383Sand & Gravel 383 403Clay 403 408STATIC WATER LEVEL 200 Feet

If flowing, closed in pressure \_\_\_\_\_ PSI

GPM flow \_\_\_\_\_ through \_\_\_\_\_ inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other

If other, specify \_\_\_\_\_

Can well be completely shut in? \_\_\_\_\_

## WELL TEST DATA:

☒ Pumped☒ Bailed☐ OtherDescribe: Well Was Bailed & FirstPump at 260 feet for8 Hrs at 12 GPM

Pumping Level Below Land Surface

\_\_\_\_\_ ft. After \_\_\_\_\_ Hrs. pumped \_\_\_\_\_ GPM

\_\_\_\_\_ ft. After \_\_\_\_\_ Hrs. pumped \_\_\_\_\_ GPM

\_\_\_\_\_ ft. After \_\_\_\_\_ Hrs. pumped \_\_\_\_\_ GPM

## REMARKS:

Well was Very GoodPump set at 260This well was drilled under license # 28

And this report is true and accurate.

Drilling firm Greene Well Drilling

Signature of License Representative:

E. H. Greene

Signature of Well Owner:

Larry Dunlavy

Date

1-29-92