SOUTH DAKOTA WATER WELL COMPLETION REPORT

10-85

Location ¼SE¼ Sec 4 Twp 117 Rg 55

County Codington

Please mark well location with an "X"



Well Completion Date 7-2-91

PROPOSED USE:
☐ Domestic ☐ Municipal ☐ Test Holes
☐ Irrigation ☐ Industrial ☒ Stock

Method of Drilling:

CASING DATA:
☐ Steel ☒ Plastic ☐ Other
If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
LB/FT	4" IN	FT	FT	IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUT:
Was the well grouted? ☒ YES ☐ NO
To what depth? 440 FEET
What is grouting material? Cement
If cement, number of sacks?
Describe grouting procedure
What was grout weight? LB/GAL

SCREEN: ☐ Perforated pipe ☒ Manufactured
Diameter 4" IN Length 20 FEET
Material
Slot Size 10 Set From 445 Feet To 465 Feet
Slot Size Set From Feet To Feet
Slot Size Set From Feet To Feet
Other information

Was a packer or seal used? ☐ YES ☒ NO
If so, what material?
Describe packer(s) and location?

Was well disinfected upon completion? ☐ YES ☐ NO
Explain
Bacteriological analysis ☒ YES ☐ NO
Laboratory sent to

Well Owner:
Name DANNY SHARP
Address HEN[illegible]

Well Log: Depth

Formation	From	To
Yellow Clay	0	20
Clay	20	220
Light Gray Sand	220	440
Clay	440	465
	465	470

Kpe 1355'



Elev 1820'

STATIC WATER LEVEL 180 Feet
If flowing: closed in pressure PSI
GPM flow through inch pipe
Controlled by ☐ Valve ☐ Reducers ☐ Other
If other; specify
Can well be completely shut in?

WELL TEST DATA:
☒ Pumped
☒ Bailed Describe:
☐ Other
Pumping Level Below Land Surface
ft. After Hrs. pumped GPM
ft. After Hrs. pumped GPM
ft. After Hrs. pumped GPM

REMARKS:

This well was drilled under license # 28
And this report is true and accurate.
Drilling firm Grewe Well Drilling
Signature of License Representative:
Signature of Well Owner:
Date 1-29-92