


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT

10-85

Location SF 1/4 1/4 Sec 7 Twp 122N Rg 58W

County Day

Please mark well location with an "X"



Well Owner:

Name Steven Karter

Address Andover SD

Plugging completion Date 9-4-1991

CHECK APPROPRIATE BOX

EXISTING WELL ☒

Well depth 80 ft

Casing material Corrugated

Casing size(s) 30"

Casing condition good

TEST HOLE ☐

Hole depth _____

Hole size _____



Describe plugging procedure: put sand in bottom of well then pumped in 2 yds of cement

Describe grout or plugging material: Cement

I gave a copy of this to the state man and the road contractor

Type of non-slip plug: _____

This well or test hole was plugged under license # 293

And this report is true and accurate.

Drilling firm Anderson Well Co

Signature of Licensed Representative Robert Anderson

Signature of Well Owner State of South Dakota

Date 9-4-1991