



SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT



Location $\frac{1}{4}$ Sec 35 Twp 113 Rg 50W

County Deuel

Please mark well location with an "X"



Well Owner:
Name Carla Sweet
Address ~~XXXXXXXXXX~~ Toronto, SD

Plugging completion Date 9-5-88

CHECK APPROPRIATE BOX

EXISTING WELL ☒

TEST HOLE ☐

Well depth 82
Casing material pvc and steel
Casing size(s) _____
Casing condition _____

Hole depth _____
Hole size _____

Describe plugging procedure: This well was re-cased 16 ft steel and 70 ft pvc 12 in and 15 ft ready mix concrete from top to 20 ft down with 40 ft of water

Describe grout or plugging material: This well sand & rock pack to

Type of non-slip plug: _____

This well or test hole was plugged under license # 455 And this report is true and accurate.

Drilling firm _____

Signature of Licensed Representative O'Connell well Drilling

Signature of Well Owner James O'Connell

Date 1-24-89