SOUTH DAKOTA WATER WELL COMPLETION REPORT

10-85

Location ~~SE~~ NE ¼ SE ¼ Sec ~~14~~ 14 Twp 9 S Rg 3 E AM 11/3/16

County FALL RIVER

Please mark well location with an "X"



Well Completion Date Dec 10 1993

PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Test Holes
☐ Irrigation ☐ Industrial ☐ Stock

Method of Drilling: ROTARY AIR

CASING DATA:
☐ Steel ☒ Plastic ☐ Other
If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
SCH 200 LB/FT	5 IN	0 FT	640 FT	7" IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUT:
Was the well grouted? ☒ YES ☐ NO
To what depth? 580 FEET
What is grouting material? CEMENT
If cement, number of sacks? 23
Describe grouting procedure TREMI LINE to PACKERS
What was grout weight? 94# 7 GAL LB/GAL

SCREEN: ☐ Perforated pipe ☒ Manufactured
Diameter 5" IN Length 60 FEET
Material PVC
Slot Size .064 Set From 580 Feet To 640 Feet
Slot Size Set From Feet To Feet
Slot Size Set From Feet To Feet
Other information

Was a packer or seal used? ☒ YES ☐ NO
If so, what material? NEORENE
Describe packer(s) and location? 2 PACKERS SET 580 + 585

Was well disinfected upon completion? ☒ YES ☐ NO
Explain 2 GAL CLOROX
Bacteriological analysis ☒ YES ☐ NO
Laboratory sent to TWIN CITY TESTING

Well Owner:
Name TED HINDSLEY
Address 3371 NO TRESCOMAS TUSON ARIZ 85749

Well Log:

Formation	Depth From	Depth To
FALL RIVER	0	80
FUSON	80	180
LAKOTA	180	380
MORRISON	380	460
SUNDANCE	460	640

STATIC WATER LEVEL 320 Feet
If flowing: closed in pressure PSI
GPM flow through inch pipe
Controlled by ☐ Valve ☐ Reducers ☐ Other
If other; specify
Can well be completely shut in?

WELL TEST DATA:
☒ Pumped PUMPED from to
☐ Bailed Describe: 9 GPM
☐ Other
Pumping Level Below Land Surface
ft. After Hrs. pumped GPM
ft. After Hrs. pumped GPM
ft. After Hrs. pumped GPM

REMARKS:

FEB 1994 DIVISION OF WATER RIGHTS Rapid, SD

This well was drilled under license # 415
And this report is true and accurate.
Drilling firm RABY DRILLING
Signature of License Representative: Russell L Raby
Signature of Well Owner: Ted Hindsley
Date 2/24/94