

07-92

Well Completion Date 4-21-94

Address: White Wood SD
Owl Creek

DEPTH

[illegible]**LOCATION:**

Distance from nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)? none ft. from _____ (identify source).

PROPOSED USE:

- ☐ Domestic Stock ☐ Municipal ☐ Business ☐ Test Holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING:

CASING DATA:

- ☐
- Steel
- ☒
- Plastic
- ☐
- Other

If other describe.

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
200 LB/FT	5 IN	71 FT	120 FT	8 IN
_____ LB/FT	_____ IN	_____ FT	_____ FT	_____ IN
_____ LB/FT	_____ IN	_____ FT	_____ FT	_____ IN

GROUTING DATA

Grout Type	No. of Sacks	Grout Weight	From	To
portland	2	65 gal	lb./gal	ft. 20 ft.
			lb./gal	ft. ft.

Describe grouting procedure.

SCREEN: ☒ Perforated pipe ☐ Manufactured

Diameter 5 IN Length 20 FEET
Material PVC
Slot Size 1/8" x 6" Set From 60 Feet to 120 Feet
Other information _____

WAS A PACKER OR SEAL USED? ☐ YES ☒ NO

If so, what material?

Describe packer(s) and location?

DISINFECTION:

Was well disinfected upon completion? ✓ YES, How: chlorine
 _____ NO, Why Not? _____

STATIC WATER LEVEL 40' Feet

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced Flowrate _____ GPM

Can well be completely shut in? _____

WELL TEST DATA:

- ☒ Pumped Describe: _____
☐ Bailed _____
☐ Other _____


Pumping Level Below Land Surface

110 ft. After 2 Hrs. pumped 3.5 GPM

_____ ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate _____ GPM

REMARKS



This well was drilled under license # 396

And this report is true and accurate.

Drilling firm Kenya

Signature of License Representative:

Signature of Well Owner or Equitable Property Holder:

Date: 7-21-94

Laboratory sent to for water quality analysis Pierre