

07-92

County Meade

W

North

E

1 Mile

Well Completion Date

Distance from nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)? none ft. from _____ (identify source).

☒ Domestic Stock ☐ Municipal ☐ Business ☐ Test Holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

Cable msg

☐ Steel ☒ Plastic ☐ Other

If other describe

PIPEWEIGHT	DIAMETER		FROM	TO	HOLE DIAMETER
200# LB/FT	5	IN	+1	FT	150 FT 8" IN
LB/FT	IN		FT	FT	IN
LB/FT	IN		FT	FT	IN

Grout Type	No. of Sacks	Grout Weight	From	To
peritland	2	6 1/2 gal	0	40
		lb./gal	ft.	ft.
		lb./gal	ft.	ft.

Describe grouting procedure pressure

Diameter _____ IN Length _____ FEET

Material _____
Slot Size 1" x 6" Set From 100 Feet to 150 Feet

Other information

If so, what material?

Describe packer(s) and location?

Was well disinfected upon completion? ☒ YES, How: chlorine
☐ NO, Why Not? _____

Laboratory sent to for water quality analysis Pierce

Well Owner: Bud Baker
Business Name: _____
Address: RR Faith SD

DEPTH

FORMATION

FROM

TO

sandy loam	0	32
gravel ^{some} water	32	38
shale	38	100
rock layer	100	102.5
shale	102.5	112
water sand ^{some} water	112	114
Pierre shale	114	150

STATIC WATER LEVEL 50' Feet

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced Flowrate _____ GPM

Can well be completely shut in? _____

☒ Pumped Describe: _____
☐ Bailed _____
☐ Other _____


Pumping Level Below Land Surface

130' ft. After 1 Hrs. pumped 4 GPM

_____ ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate _____ GPM

REMARKS



This well was drilled under license # 396

And this report is true and accurate.

Drilling firm Karl's Drilling

Signature of License Representative:

Signature of Well Owner or Equitable Property Holder:

Date: 7-31-94