


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT

10-85

Location SE 1/4 SE 1/4 Sec 18 Twp 123N Rg 62W

County

BrownPlease mark well
location with
an "X"

Well Owner:

Name Alan LanpheteAddress 39494 123rd StreetBath, S.D. 57219Plugging completion Date 5-25-06

CHECK APPROPRIATE BOX

EXISTING WELL

☒ Monitor Wells

TEST HOLE

☐

Well depth

20'

Casing material

Schedule 40 PVC

Casing size(s)

2"

Casing condition

Good

Hole depth

Hole size

Describe plugging procedure:

Remove well protectors, Cut Casings
2' below ground level and grout wells,

Describe grout or plugging material:

Cement

Type of non-slip plug:

None

This well or test hole was plugged under license #

647

And this report is true and accurate.

Drilling firm

Gem Star Inc.

Signature of Licensed Representative

Signature of Well Owner

Date

RECEIVED

JUN - 7 2006

WATER RIGHTS
PROGRAM