


WELL DRILLERS REPORT
SOUTH DAKOTA WATER RIGHTS COMMISSION

4-78

Well Owner: Bill Schroeder
 Name Bill Schroeder
 Address Plankinton So Dak

Water Level information:
 Static water level 190 below land surface
 If flowing: closed in pressure PSI
 rate of low GPM
 Controlled by:
☐ Valve ☐ Reducers ☐ Other
 If other; specify



Well Test Data:
☒ Pumped 1/2 Hp Suck
☐ Bailed Describe:
☐ Other
 Pumping Level Below Land Surface
 ft. After Hrs. pumped 8 GPM
 " " " " " "
 " " " " " "

County Aurora
NW 1/4 NW 1/4 SE 1/4 Sec. 18 Twp. 103N Rg. 64W

Proposed Use:
☐ Domestic ☐ Municipal ☐ Test Holes
☐ Irrigation ☐ Industrial ☒ Stock

Method of Drilling:
☒ Forward Rotary ☐ Bored ☐ Jetted
☐ Reverse Rotary ☐ Cable ☐ Other

Well Construction:
 Diameter of Hole 4"
 Depth 220
 Casing ☐ Steel ☐ Concrete
☒ Plastic ☐ Other
 If other, specify

Was casing end left open yes
 Was a well screen installed yes
 Describe Well Screen
 Diameter 4" Material PVC
 Slot size 1/16"
 Was well gravel packed
 Was well grouted
 Was water sample taken

Well Log:

Formation	Depth	
	From	To
yellow clay	0	25
blue clay	25	75
blue clay shale	75	180
hard coarse sand	180	188
grey marl	188	200
chalk	200	220

(Use Back if Necessary)

Date Completed: 8-22-81

Driller: Johnson Drilling 51
 Driller's or Firm's Name License NO.
Plankinton So Dak
 Address
Daniel Johnson 8-24-81
 Signed By Date

Remarks:

