Name Gilbert Hunsley

Address Pierre

So Dak 57501

4-5643

AAA WELL CO.

Paul C. Worm 223-2241

PIERRE, SOUTH DAKOTA 57501

№ 1619

DATE 21 Sept 77

WELL LOCATION

Sketch map location must agree with written location.

NORTH

½ Mile

County Hughes

1/4 NW 1/4 SE / Sec. 18 Twp. 111 N. Rg. 78 W.

WELL CONSTRUCTION

Diameter of hole 6 1/4 inches. Depth 89 feet.

Casing: ☐ Steel ☑ Plastic ☐ Concrete

☐ Threaded ☐ Welded ☐ Other

If other, specify

Pipe Weight:	Diameter:	From:	To:
lb/ft.	inches	feet	feet
lb/ft.	inches	feet	feet

If other, specify

PROPOSED USE

☑ Domestic ☐ Irrigation ☐ Industrial

☐ Stock ☐ Municipal ☐ Test Hole

METHOD DRILLED

☐ Cable ☐ Reverse Rotary ☐ Bored

☑ Forward Rotary ☐ Jetted ☐ Other

If other, specify

WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
89 ft well		
15' pea		

(Use separate sheet if necessary.)

NOV 1977 RECEIVED STATE WATER RIGHTS COMM. Pierre, S.D.

WATER QUALITY

Was a water sample collected for chemical analysis?

☐ Yes ☑ No

PUMP INSTALLATION

Company name and size of pump _____ H.P. _____

Type of pump _____ Capacity G.P.M. _____

Depth of pump placement _____ ft., Date pump intalled _____

Depth to top of water producing aquifier _____

Depth to static water level _____

Name of producing aquifier (if known) _____

Was bottom left open end? ☐ Yes ☑ No

Was a well screen installed? ☑ Yes ☐ No

Material Plastic Diameter 4 inche

(Stainless steel, plastic, etc.)

Slot size 30 set from 74 feet to 89 fee

Cash	Check	Charge	On Acct