


SOUTH DAKOTA WATER WELL COMPLETION REPORT

10-85

Location ~~NE 1/4 NE 1/4~~ Sec 23 Twp 28-72 Rg 49 RCounty Roberts

Please mark well location with an "X"

Well Completion Date 11/03/04

PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Test Holes
☐ Irrigation ☐ Industrial ☐ Stock

Method of Drilling:

Forward Rotary

CASING DATA:

☐ Steel ☒ Plastic ☐ Other

If other describe _____

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
LB/FT <u>4</u> IN	<u>0</u> FT	<u>49</u> FT	<u>6 7/8</u> IN	
LB/FT _____ IN	_____ FT	_____ FT	_____ IN	
LB/FT _____ IN	_____ FT	_____ FT	_____ IN	
LB/FT _____ IN	_____ FT	_____ FT	_____ IN	

GROUT:

Was the well grouted? ☐ YES ☐ NOTo what depth? 35 FEETWhat is grouting material? port cementIf cement, number of sacks? 4Describe grouting procedure Pump through tremie

What was grout weight? _____ LB/GAL

SCREEN: ☐ Perforated pipe ☒ ManufacturedDiameter 3 IN Length 4 FEETMaterial SSSlot Size 12 Set From 49 Feet To 53 Feet

Slot Size _____ Set From _____ Feet To _____ Feet

Slot Size _____ Set From _____ Feet To _____ Feet

Other information _____

Was a packer or seal used? ☒ YES ☐ NOIf so, what material? steel/rubberDescribe packer(s) and location? 49'Was well disinfected upon completion? ☒ YES ☐ NOExplain granular chlorineBacteriological analysis ☐ YES ☒ NO

Laboratory sent to _____

Well Owner:

Name Ben Bget BexlAddress 47125 SD Highway 127Well Log: Rosholt SD 57360

Formation

	From	To
<u>Yellow Clay</u>	<u>0</u>	<u>8</u>
<u>Brown Sand</u>	<u>8</u>	<u>11</u>
<u>Yellow clay</u>	<u>11</u>	<u>24</u>
<u>Brown sand</u>	<u>24</u>	<u>26</u>
<u>yellow clay</u>	<u>26</u>	<u>34</u>
<u>Dark Brown clay</u>	<u>34</u>	<u>41</u>
<u>Coarse brown sand</u>	<u>41</u>	<u>49</u>
<u>Fine gray sand (clay stringers)</u>	<u>49</u>	<u>52</u>
<u>Brown/gray sand</u>	<u>52</u>	<u>53</u>

STATIC WATER LEVEL 35 Feet

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other

If other: specify _____

Can well be completely shut in? _____

WELL TEST DATA:

☒ Pumped☐ Bailed☐ OtherDescribe: 6 GPM for 6 hrs.

Pumping Level Below Land Surface

_____ ft. After _____ Hrs. pumped _____ GPM

_____ ft. After _____ Hrs. pumped _____ GPM

_____ ft. After _____ Hrs. pumped _____ GPM

REMARKS:

Drilled by Norton Falk.
Sand set in was gray with brown streaks also clay stringers. Didn't look that great but we sealed the top of well and it pumped fine. Previous well did 36 AM, same depth.

This well was drilled under license # 336

And this report is true and accurate.

Drilling firm Falk Bros

Signature of License Representative: _____

Signature of Well Owner: _____

Date 11-24-04

2-15-05