


## SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT

10-85

Location NE 1/4 NW 1/4 Sec 2 Twp 121N Rg 64WCounty  
BrownPlease mark well  
location with  
an "X"

Well Owner:

Name Warner Cenex Bulk PlantAddress PO Box 200Warner, S.D. 57479Plugging completion Date 10-28-05

## CHECK APPROPRIATE BOX

EXISTING WELL

☒ Close all Monitor  
Wells

Well depth

15'

Casing material

Sch. 40 PVC

Casing size(s)

2" x 4"

Casing condition

Good

TEST HOLE



Hole depth

Hole size

Describe plugging procedure: Grout Wells from 15' to within 2'  
Ground level. Remove Top 2' and Casing protection.  
Top 2' backfilled with native materials.

Describe grout or plugging material: Cement

RECEIVED

NOV 14 2005

WATER RIGHTS  
PROGRAMType of non-slip plug: NoneThis well or test hole was plugged under license # 647 And this report is true and accurate.

Drilling firm

Gem Star Inc.

Signature of Licensed Representative

Mike Jarama

Signature of Well Owner

Tracy Weig

Date

11-2-05

11-14-05