

SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT


11-02

Location: NE ¼ SW ¼ Sec 8 Twp 101N Rg 49W

Well Owner:

County

Minnehaha

Please mark well
location with
an "X"

Name:

Land O Lakes, Mr. V.A. Hammer

Address:

Mail Station 0085, P.O. Box 64101

City, State, Zip: St Paul

MN

55164-0101

Comments:

Plugging Completion Date 10/25/2006

CHECK APPROPRIATE BOX

EXISTING WELL ☒TEST HOLE ☐

Well depth 30 feet

Casing material Steel

Casing size(s) 12 inch

Casing condition Good

Hole depth

Hole size

RECEIVED

JAN - 2 2007

WATER RIGHTS
PROGRAM

Describe plugging procedure:

The well was filled with sand to a depth of 12 feet below the top of casing. The well was filled with concrete grout from 12 feet to 2 feet below top of casing.

Describe grout or plugging material:

A 3000 psi grout consisting of sand and cement was used for plugging.

Type of non-slip plug:

This well or test hole was plugged under license # 530 and this report is true and accurate.

Drilling firm: Tetra Tech, Inc. (formerly Maxim Technologies)

Signature of Licensed Representative:

Signature of Well Owner:

Date:

12/28/06

1-4-07