


07-92

Date: 10-25-05

100-60-11



DIVISION OF ADMINISTRATION

Public Health Laboratory

615 East Fourth Street
Pierre, South Dakota 57501-1700
605/773 3368 FAX 605/773 1613
www.southdakotalab.com

Submitter copy to:

* Page 1 of 1*

Date: 11/23/2005

GROOMS DRILLING INC-101729
BOX 226
VALENTINE, NE 69201

Spec #: E05WB013761

Subm #:

Lab: ENV CHEMISTRY

Tel #: (605) 773-3368

Source

GROOMS DRILLING

Date Rcvd: 10/25/2005

Time Rcvd: 0800

Date Coll: 10/24/2005

Time Coll: 1445

Spec Type: WATER

Coll Site: WELL

Coll By: SCOTT GROOMS

Date drilled: 6-05

Drilled by: GROOMS DRILLING

Telephone Numb* 4023763844

Well Depth: 145

Sample County: TODD

Township: 39N

Range: 33W

Section: 14

Supply Type: PRIVATE

Well Depth: 145

Well Diameter: 5

Sample Purpose: ROUTINE

Final Results

Sulfate

<10.0 mg/L

Sodium

4.4 mg/L

Conductivity

353 umho/cm

7 Coliform-5 Tube MPN

Bacteriologically safe at the time of sampling.

Nitrate

5.1 mg/L

Limit: 10.0

NITRATE RESULT: SAFE AT TIME OF SAMPLING.

RECEIVED

NOV 30 2005

WATER RIGHTS
PROGRAM