

SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT


10-85

Location NE 1/4 NE 1/4 Sec 12 Twp 8N Rg 2E

County

BUTTE CO.

Please mark well location with an "X"



Well Owner:

Name Butte County ShopAddress 830 6th Ave, 57717Plugging completion Date 11-3-09

CHECK APPROPRIATE BOX

EXISTING WELL



TEST HOLE

Well depth 140' Pump SettingCasing material 160NCasing size(s) 4" ID, Run Tube to 100' 10" ID CementCasing condition Good on topLog US Geo LogicalHole depth 140' Pump SettingHole size 100' - 10" surface

RECEIVED

NOV 17 2009

WATER RIGHTS PROGRAM

Describe plugging procedure: Barney Reising Bellefonte
Run 140' 1" Trench Tube 140'
Run 100' 1" " " 100' in 10" surface

Describe grout or plugging material: 40 SKS with 60% water per SK. Crock Ready mix
pumped through tube by Geop's Rig.

This well is ALOT Deeper than was told.

Type of non-slip plug:

This well or test hole was plugged under license # 327 And this report is true and accurate.Drilling firm Geop DrillingSignature of Licensed Representative Geop DrillingSignature of Well Owner Donal AdamsDate 11-15-09

11-17-09