

SOUTH DAKOTA WATER WELL COMPLETION REPORT

07-92


Location SW 1/4 NE 1/4 Sec 18 Twp 410 Rg 4E
County LAWRENCE

Please mark well location with an "X"

W

E

Well Completion Date

9-3-13

LOCATION:

Distance from nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)? 150 ft. from Acorn Field (identify source).

PROPOSED USE:

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test Holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING:

Air RotaryCASING DATA: ☒ Steel ☒ Plastic ☐ Other

If other describe _____

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
<u>Steel</u> LB/FT <u>6</u> IN <u>0</u> FT <u>30</u> FT <u>8.75</u> IN				
<u>160</u> LB/FT <u>4.5</u> IN <u>30</u> FT <u>65</u> FT <u>6</u> IN				
_____ LB/FT _____ IN _____ FT _____ FT _____ IN				

GROUTING DATA

Grout Type	No. of Sacks	Grout Weight	From	To
<u>Portland</u>	<u>6</u>	<u>94/lb</u> lb./gal	<u>5</u> ft	<u>30</u> ft
_____	_____	_____ lb./gal	_____ ft	_____ ft

Describe grouting procedure Grouted thru tube outside casingSCREEN: ☐ Perforated pipe ☒ Manufactured

Diameter _____ IN Length _____ FEET

Material _____

Slot Size 025 Set From 45 Feet to 65 Feet

Other information _____

WAS A PACKER OR SEAL USED? ☐ YES ☒ NO

If so, what material? _____

Describe packer(s) and location? _____

DISINFECTION: Was well disinfected upon completion?

☒ YES, How: Chlor☐ NO, Why Not? _____

Laboratory sent to for water quality analysis _____

Well Owner: Jody Krajnik

Business Name: _____

Address: 804 Rockwood Dr.
Gillette Wyo. 82716

WELL LOG:

DEPTH

FORMATION

FROM

TO

<u>Gravel Clay Mix</u>	<u>0</u>	<u>15</u>
<u>Black Shist with</u>	<u>15</u>	<u>65</u>
<u>Iron Pyrite</u>		

STATIC WATER LEVEL 0 Feet

If flowing: closed in pressure _____ PSI

GPM flow 25 through _____ inch pipeControlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced Flowrate _____ GPM

Can well be completely shut in? _____

WELL TEST DATA:

☐ PumpedDescribe: Air Assisted☐ Bailed☒ Other _____

Pumping Level Below Land Surface

_____ ft. After _____ Hrs. pumped _____ GPM

_____ ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate _____ GPM

REMARKS

Hit Water 45'
Producing @ 259GPMThis well was drilled under license # 638

And this report is true and accurate.

Drilling firm Roman DrillingSignature of Licensee Representative: But RomanSignature of Well Owner or Equitable Property Holder: Jody Krajnik9/15/13Date: 9/15/13

RECEIVED

OCT 15 2013

WATER RIGHTS
PROGRAM