


SOUTH DAKOTA WATER WELL COMPLETION REPORT

07-92

Location SE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec 25 Twp 98 Rg 53County Turner

Please mark well location with an "X"



Well Completion Date

8/20/13

LOCATION:

Distance from nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)? 700 ft. from house (identify source).

PROPOSED USE:

☐ Domestic/Stock ☐ Municipal ☐ Business ☐ Test Holes
☒ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING:

Boring MachineCASING DATA: ☐ Steel ☒ Plastic ☐ Other

If other describe _____

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
_____ LB/FT	<u>18</u> IN	<u>0</u> FT	<u>27</u> FT	<u>30</u> IN
_____ LB/FT	_____ IN	_____ FT	_____ FT	_____ IN
_____ LB/FT	_____ IN	_____ FT	_____ FT	_____ IN

GROUTING DATA

Grout Type	No. of Sacks	Grout Weight	From	To
_____	_____	_____ lb./gal	_____ ft	_____ ft
_____	_____	_____ lb./gal	_____ ft	_____ ft

Describe grouting procedure peg rock 10' to 47'
concrete 6' to 10' topsoil 0'-6'SCREEN: ☐ Perforated pipe ☒ ManufacturedDiameter 18 IN Length 20 FEETMaterial plasticSlot Size .085 Set From 27 Feet to 47 FeetOther information seeWAS A PACKER OR SEAL USED? ☐ YES ☒ NO

If so, what material? _____

Describe packer(s) and location? _____

DISINFECTION: Was well disinfected upon completion?

____ YES, How: _____

____ NO, Why Not? _____

Laboratory sent to for water quality analysis _____

Well Owner: Kurt Schneiderman

Business Name: _____

Address: 28265 470th Av
Lennox SD. 57039

WELL LOG:

FORMATION	DEPTH	
	FROM	TO
<u>Topsoil</u>	<u>0'</u>	<u>6'</u>
<u>clay + gravel mix</u>	<u>6'</u>	<u>12'</u>
<u>water bearing sand + gravel</u>	<u>12'</u>	<u>47'</u>

STATIC WATER LEVEL 11 Feet

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced Flowrate _____ GPM

Can well be completely shut in? _____

WELL TEST DATA:

☐ Pumped Describe: _____☐ Bailed _____☐ Other _____

Pumping Level Below Land Surface

_____ ft. After _____ Hrs. pumped _____ GPM

_____ ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate 500 GPM

REMARKS

RECEIVED

MAR 19 2014

WATER RIGHTS PROGRAM

RECEIVED

MAR 19 2014

WATER RIGHTS PROGRAM

This well was drilled under license # 478

And this report is true and accurate.

Drilling firm Reiners Well DrillingSignature of License Representative: Jon ReinerSignature of Well Owner or Equitable Property Holder: Kurt SchneidermanDate: 12-30-13