


SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02

Location NE ¼ NE ¼ Sec 8 Twp 112N Rg 52WCounty BROOKINGSPlease mark well
location with an "X"

Well Completion Date

08-21-16

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?

2,500.0 ft. from LP SANITARY SEWER (identify source)

PROPOSED USE:

☒ Domestic/Stock
☐ Irrigation
 ☐ Municipal
☐ Industrial
 ☐ Business
☐ Institutional
 ☐ Test holes
☐ Monitoring well

METHOD OF DRILLING:

DIRECT ROTARY

CASING DATA:

☐ Steel
 ☒ Plastic
 ☐ Other

If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
<u>21.0</u> LB/FT	<u>5.00</u> IN	<u>0.0</u> FT	<u>131.0</u> FT	<u>8.74</u> IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
<u>GRTWELDF</u>	<u>11</u>	<u>54.0</u> Lb/gal	<u>0.0</u> Ft	<u>125.0</u> Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

TREMIE LINE

SCREEN:

☐ Perforated pipe
 ☒ Manufactured
 Diameter 5.00 Inches Length 20.0 FeetMaterial PLASTICSlot Size .025 Set From 131.0 Feet to 151.0 Feet

Other information

WAS A PACKER OR SEAL USED?

☐ Yes
 ☐ No

If so, what material?

Describe packer(s) and location

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? HTH
☐ No, Why Not?
Lab to which water
quality sample sent for analysis

NO PUMP

Well Owner: JASON AND MARK FUHR

Business Name:

Address: 45474 198TH STCity, State, Zip: ARLINGTON SD

WELL LOG:

FORMATION	DEPTH	
	FROM	TO
TOP SOIL	0	3
YELLOW CLAY	3	18
BLUE CLAY	18	82
GREY SAND FINE	82	86
BLUE CLAY	86	131
YELLOW SAND MIXED	131	151

STATIC WATER LEVEL

20.0 FEET

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ Inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced flow rate _____ GPM

Can well be completely shut in?

WELL TEST DATA:

☒ Pumped Describe: AIR LIFT
☐ Bailed

☐ Other

Pumping Level Below Land Surface

80.0 Ft. After 4.0 Hrs. pumped 100.0 GPM

_____ Ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate: _____ GPM

REMARKS

 JOB ADDRESS
3410 MAIN AVE S
BROOKINGS SD 57006

RECEIVED

FEB - 1 2017

WATER RIGHTS
PROGRAM

XXXXXXXXXXXX

This well was drilled under license # 689 and this
report is true and accurate.Drilling firm: KAISER WELL DRILLING INC

Signature of License Representative:

Signature of Well Owner or Equitable Property Holder:

Date: _____